


SZS CONSULTING GROUP

DRAFT ADA TRANSITION PLAN UPDATE
NEIGHBORHOOD AREA 7 CHASE
SEPTEMBER 20, 2011



CITY OF CITRUS HEIGHTS

The Citrus Heights (CHASE) Neighborhood Association

The Citrus Heights CHASE Neighborhood Area is located in the northeast part of Citrus Heights. The area is shared with Area 8 and is comprised of mostly mixed residential units with duplexes, apartment complexes, and single-family homes. There are five parks and one elementary school in this area and the border roads are Twin Oaks Ave, Sunrise Boulevard, Watchel Way and Oak Avenue. Old Auburn Road is the border between CHASE Neighborhood areas 7 & 8.

Conditions – CHASE Area 7

Most of the sidewalks in this area are pre-1992 construction, which were identified with common issues such as non-compliant cross slopes, clear width issues, abrupt changes of level, and poor surface conditions. Many pre-1992 curb ramps were identified with multiple barriers to access. A new subdivision development in the northeast segment of the area was identified with non-compliant sidewalk cross slopes.


Old Auburn Road was identified with a number of areas lacking improved sidewalks where pedestrians are forced to use the shoulder pavement as the path of travel in areas with high vehicular traffic. The interior sidewalks of CHASE Neighborhood Area 7 were identified with pre-1992 construction with common barriers such as non-compliant cross slopes, clear width issues, and abrupt changes of level.

Many pre-1992 curb ramps have multiple barriers to access with some corners that were identified with “depressed curbs” which are not actual curb cuts but depressed areas in the concrete at intersection corners that it is assumed were intended to assist with travel over the existing vertical or rolled curb. The post-1992 curb ramps in the same areas were identified with minor compliance issues such as non-compliant detectable warnings and curb ramp landings.

Sunrise Boulevard and Old Auburn Road also lack improved sidewalks in some locations although sidewalks have been provided in the areas where the two arterial roadways meet. Other compliance issues were identified in the sidewalks and bus stops on these arterial roadways.

Statistics

An intersection inventory was complied as part of the field assessment process. In the CHASE Area, 8 intersections were found to have no barriers to access and a total of 797 barriers were identified. The compliant intersections in CHASE Area 7 are identified as follows:



#	Location	Notes
1	Keesee Wy and Zephyr Creek Ct - Corners A,B	Two - way intersection corners A,B compliant
2	Glen Tree Dr and Hanson Ave - Corner A,D Compliant	Two - way intersection corners A,D compliant
3	Glen Echo St and Glen Eva Wy - Corners A,D	Two - way intersection corners A,D compliant
4	Glen Valley Cir and Glen Tree Dr - Corners B,C	Two - way intersection corners B,C compliant
5	Glen Tree Dr and Glen Eva Wy - Corners B,C	Two - way intersection corners B,C compliant
6	English Oak Wy and Holm Oak Wy - Corners B,C	Two - way intersection corners B,C compliant
7	Glen Tree Dr and Glen Valley Cir - Corners B,C	Two - way intersection corners B,C compliant
8	Garry Oak Dr and English Oak Wy - Corners B,C	Two - way intersection corners B,C compliant

Barrier severity ratings were calculated for the 5 ratings assigned as follows:

<i>Severity 1 (Necessary to Remove)</i>	<i>460 or 58% of total barriers</i>
<i>Severity 2 (Recommended to Remove)</i>	<i>191 or 24% of total barriers</i>
<i>Severity 3 (Hindrance to Access)</i>	<i>120 or 15% of total barriers</i>
<i>Severity 4 (Low Severity Barrier)</i>	<i>26 or 3% of total barriers</i>
<i>Severity 5 (Technically Infeasible to Remove)</i>	<i>0 or 0% of total barriers</i>

Barrier Removal Priority Assignment

The draft barrier removal priorities were assigned to the pedestrian facilities using the criteria described below:

Priority 1 - Primary arterial roadways where the majority of bus routes are located

Antelope Blvd
Old Auburn Blvd
Sunrise Blvd

Priority 2 – Major collectors where remaining bus routes are located or where commercial centers, schools, parks, churches, state or local agency facilities exist

Conover Drive
Newbridge Way
Twin Oaks Blvd

Priority 3 - Pedestrian routes leading from points of arrival at bus routes to schools, parks or other public accommodations

Canyon Oak Avenue
Glen Tree Avenue

Priority 4 – Remaining residential areas

Cost Estimates

The total cost for barrier removal within this draft ADA Transition Plan update was calculated as follows:

Cost Estimate Total: \$17,105,350.00

Barrier removal takes place through annual phases that are determined according to the barrier priority assigned and existing budgetary constraints. Draft barrier removal priorities have the following costs associated with each priority assigned:

Cost Estimate - Priority 1: \$1,818,050.00

Cost Estimate - Priority 2: \$2,070,800.00

Cost Estimate - Priority 3: \$1,589,125.00

Cost Estimate - Priority 4: \$11,627,375.00

Further input is required to complete the ADA Transition Plan. Each Neighborhood Area (NA) must be reviewed by designated Citrus Heights City staff to determine whether overall priorities shall be set per NA or overall throughout the city. Other constraints were taken into consideration while compiling the cost estimates.

1. Currently all barriers are assigned a priority for removal. Some areas may not be used as pedestrian facilities, may be unimproved and could remain so until a request for accommodations is received by the City.
 - a. Assistance in prioritizing areas that lack sidewalk is required. Some segments are lengthy and may not be planned for improvements in the long or short term.
2. Cost estimates have been manually reviewed and corrected
 - a. In instances where more than one barrier exists at a curb ramp, cost estimates for curb ramp barriers are often manually changed to ensure that cost estimates do not exceed \$2,500. In these instances, the cost estimate for the first barrier (i.e. 24A, of 24B, 24C and 25D) is listed with a cost estimate of \$2,500 and the remaining barriers are listed with a cost of \$0. This may occur even when the first barrier listed is not ordinarily estimated as high as \$2,500.
 - b. Driveways with multiple slopes were assigned a severity 1 rating, rather than a rating that corresponded to the slope of only one of the measurements taken.
 - c. Bus stop benches with multiple barriers were only assigned one cost estimate for one accessible bench.

The following barrier data sheets must be reviewed in draft form to provide input for the final report.

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5072A
Location:	Old Auburn Rd and Oakwood Hills Ct - Corner A				
X Coordinate:	-121.24353				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	7.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5072B
Location:	Old Auburn Rd and Oakwood Hills Ct - Corner A				
X Coordinate:	-121.24353				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	11.4% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5072C
Location:	Old Auburn Rd and Oakwood Hills Ct - Corner A				
X Coordinate:	-121.24353				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level(4.1% to 4.9%)		
As Built Desc:	4.5% slope at landing		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5072D
Location:	Old Auburn Rd and Oakwood Hills Ct - Corner A				
X Coordinate:	-121.24353				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5073
Location:	Old Auburn Rd and Oakwood Hills Ct - Corner B				
X Coordinate:	-121.24342				
Y Coordinate:	38.71753				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5074
Location:	Oakwood Hills Ct - East				
X Coordinate:	-121.24358				
Y Coordinate:	38.71767				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	712	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$89,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5075
Location:	Oakwood Hills Ct - West				
X Coordinate:	-121.24572				
Y Coordinate:	38.71833				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	624	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$78,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5076A
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner A				
X Coordinate:	-121.24522				
Y Coordinate:	38.71674				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Three - way intersection corners A,B,C
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5076B
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner A				
X Coordinate:	-121.24522				
Y Coordinate:	38.71674				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5076C
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner A				
X Coordinate:	-121.24522				
Y Coordinate:	38.71674				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (5.9% - 6.5%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (5.9% - 6.5%)		
As Built Desc:	6.1% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,B,C		

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5077A

Location: Oakwood Hills Ct and Acorn Creek Ct - Corner B

X Coordinate: -121.24529

Y Coordinate: 38.7169

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 5.5% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A,B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5077B

Location: Oakwood Hills Ct and Acorn Creek Ct - Corner B

X Coordinate: -121.24529

Y Coordinate: 38.7169

Barrier Area: Curb Ramps

Barrier Type: Running Slope - Existing (9.0% to 9.4%)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.1



As Built Meas: 1 Quantity: EACH

Description: Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)

As Built Desc: 9.1% running slope

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A,B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5077C

Location: Oakwood Hills Ct and Acorn Creek Ct - Corner B

X Coordinate: -121.24529

Y Coordinate: 38.7169

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (>5.0% or more)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (>5.0% or more)

As Built Desc: 5.2% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A,B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5077D

Location: Oakwood Hills Ct and Acorn Creek Ct - Corner B

X Coordinate: -121.24529

Y Coordinate: 38.7169

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Three - way intersection corners A,B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5078A
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner C				
X Coordinate:	-121.24518				
Y Coordinate:	38.71687				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.3% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A,B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5078B
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner C				
X Coordinate:	-121.24518				
Y Coordinate:	38.71687				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	9.8% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A,B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5078C
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner C				
X Coordinate:	-121.24518				
Y Coordinate:	38.71687				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level(4.1% to 4.9%)		
As Built Desc:	4.1% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5078D
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner C				
X Coordinate:	-121.24518				
Y Coordinate:	38.71687				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Three - way intersection corners A,B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5078E
Location:	Oakwood Hills Ct and Acorn Creek Ct - Corner C				
X Coordinate:	-121.24518				
Y Coordinate:	38.71687				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (5.1% - 5.8%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (5.1% - 5.8%)		
As Built Desc:	5.4% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Three - way intersection corners A,B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5079
Location:	Oakwood Hills Ct - West				
X Coordinate:	-121.24524				
Y Coordinate:	38.71671				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	63	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$7,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5080
Location:	Oakwood Hills Ct and Old Auburn Rd - Corner A				
X Coordinate:	-121.24505				
Y Coordinate:	38.71654				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5081
Location:	Oakwood Hills Ct and Old Auburn Rd - Corner B				
X Coordinate:	-121.24492				
Y Coordinate:	38.71657				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5082
Location:	Oakwood Hills Ct - East				
X Coordinate:	-121.245				
Y Coordinate:	38.71666				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	67	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5083
Location:	Acorn Creek Ct - South				
X Coordinate:	-121.24515				
Y Coordinate:	38.71692				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	266	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$33,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5084A
Location:	Acorn Creek Ct - North				
X Coordinate:	-121.24493				
Y Coordinate:	38.71762				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	287	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$35,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5084B
Location:	Acorn Creek Ct - North				
X Coordinate:	-121.24513				
Y Coordinate:	38.71706				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5085
Location:	Oakwood Hills Ct - East				
X Coordinate:	-121.24537				
Y Coordinate:	38.7169				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	490	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$61,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5086
Location:	Oakwood Hills Ct - West				
X Coordinate:	-121.24559				
Y Coordinate:	38.71821				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	680	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$85,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5087
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24405				
Y Coordinate:	38.71693				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	150	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$15,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5088
Location:	Old Auburn Rd and Wachtel Wy - Corner B				
X Coordinate:	-121.24436				
Y Coordinate:	38.71678				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Three - way intersection corners B,C,D
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5089
Location:	Old Auburn Rd and Wachtel Wy - Corner C				
X Coordinate:	-121.24441				
Y Coordinate:	38.71665				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Three - way intersection corners B,C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5090
Location:	Old Auburn Rd and Wachtel Wy - Corner D				
X Coordinate:	-121.24458				
Y Coordinate:	38.71656				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Three - way intersection corners B,C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5091
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24451				
Y Coordinate:	38.71673				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	128	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$12,800.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5092
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24513				
Y Coordinate:	38.71639				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	313	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$31,300.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			


Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5093
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24603				
Y Coordinate:	38.71587				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5094
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24606				
Y Coordinate:	38.71587				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	44" at tree branches		
Solution:	Trim trees to provide min. 48"		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5095
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24615				
Y Coordinate:	38.71581				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	331	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$41,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5096
Location:	Old Auburn Rd and Argo Dr - Corner A				
X Coordinate:	-121.2473				
Y Coordinate:	38.71521				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5097

Location: Old Auburn Rd and Argo Dr - Corner B

X Coordinate: -121.24716

Y Coordinate: 38.71531

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 13.6% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5098

Location: Argo Dr - East

X Coordinate: -121.2473

Y Coordinate: 38.71546

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 361 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$45,125.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5099
Location:	Argo Dr and Longden Cir - Corner B				
X Coordinate:	-121.24757				
Y Coordinate:	38.71647				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5100
Location:	Argo Dr and Longden Cir - Corner C				
X Coordinate:	-121.24751				
Y Coordinate:	38.71637				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5101
Location:	Longden Cir - South				
X Coordinate:	-121.24747				
Y Coordinate:	38.71637				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	250	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$31,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5102
Location:	Longden Cir - South				
X Coordinate:	-121.2466				
Y Coordinate:	38.71641				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	10.5% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5103A
Location:	Longden Cir - East				
X Coordinate:	-121.24654				
Y Coordinate:	38.71643				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	636	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$79,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5103B
Location:	Longden Cir - East				
X Coordinate:	-121.24651				
Y Coordinate:	38.71723				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5104
Location:	Longden Cir - North				
X Coordinate:	-121.2465				
Y Coordinate:	38.71817				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	9.6% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5105A
Location:	Longden Cir - North				
X Coordinate:	-121.24655				
Y Coordinate:	38.71819				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	740	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$92,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5105B
Location:	Longden Cir - North				
X Coordinate:	-121.24729				
Y Coordinate:	38.71824				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	12	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5106
Location:	Arcaro Ct - South				
X Coordinate:	-121.24797				
Y Coordinate:	38.71816				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	155	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5107

Location: Arcaro Ct and Argo Dr - Corner C

X Coordinate: -121.2474

Y Coordinate: 38.71812

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.2% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two -way intersection corners C,D

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5108

Location: Arcaro Ct and Argo Dr - Corner D

X Coordinate: -121.24748

Y Coordinate: 38.71812

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.3% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two -way intersection corners C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5109
Location:	Longden Cir - South				
X Coordinate:	-121.2473				
Y Coordinate:	38.71816				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	181	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5110
Location:	Longden Cir - South				
X Coordinate:	-121.24667				
Y Coordinate:	38.71811				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	10.1% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5111
Location:	Longden Cir - West				
X Coordinate:	-121.24663				
Y Coordinate:	38.71804				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	520	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$65,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5112
Location:	Longden Cir - West				
X Coordinate:	-121.24662				
Y Coordinate:	38.71653				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	10.5% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5113A
Location:	Longden Cir - North				
X Coordinate:	-121.24666				
Y Coordinate:	38.71652				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	250	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$31,250.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5113B
Location:	Longden Cir - North				
X Coordinate:	-121.24682				
Y Coordinate:	38.71653				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF	
Description:	Change in level greater than 1/2"			
As Built Desc:	1/2" lip in sidewalk surface			
Solution:	Grind or repair sidewalk to remove trip hazard			
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5114A
Location:	Argo Dr - East				
X Coordinate:	-121.2476				
Y Coordinate:	38.7165				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	580	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$72,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5114B
Location:	Argo Dr - East				
X Coordinate:	-121.2476				
Y Coordinate:	38.71655				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5115
Location:	Argo Dr - West				
X Coordinate:	-121.24747				
Y Coordinate:	38.71809				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	250	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$31,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5116
Location:	Argo Dr and Shoemaker Wy - Corner A				
X Coordinate:	-121.24751				
Y Coordinate:	38.71752				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5117
Location:	Argo Dr and Shoemaker Wy - Corner D				
X Coordinate:	-121.24752				
Y Coordinate:	38.7174				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5118A
Location:	Argo Dr - West				
X Coordinate:	-121.24751				
Y Coordinate:	38.71738				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	780	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$97,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5118B
Location:	Argo Dr - West				
X Coordinate:	-121.24768				
Y Coordinate:	38.71681				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5118C
Location:	Argo Dr - West				
X Coordinate:	-121.24763				
Y Coordinate:	38.71604				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5119A
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24736				
Y Coordinate:	38.71522				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	264	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$33,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5119B
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24791				
Y Coordinate:	38.71492				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5120A
Location:	Old Auburn Rd and Conover Dr - Corner A				
X Coordinate:	-121.24829				
Y Coordinate:	38.71471				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)		
As Built Desc:	3.2% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5120B
Location:	Old Auburn Rd and Conover Dr - Corner A				
X Coordinate:	-121.24815				
Y Coordinate:	38.71478				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5121
Location:	Old Auburn Rd and Conover Dr - Corner B				
X Coordinate:	-121.24815				
Y Coordinate:	38.71478				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				




As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5122A
Location:	Conover Dr - East				
X Coordinate:	-121.24824				
Y Coordinate:	38.71483				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	425	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$53,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5122B
Location:	Conover Dr - East				
X Coordinate:	-121.24831				
Y Coordinate:	38.71497				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	44" at tree branches		
Solution:	Trim trees to provide min. 48"		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5122C
Location:	Conover Dr - East				
X Coordinate:	-121.24876				
Y Coordinate:	38.71592				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5123A

Location: Conover Dr and Conover Ct - Corner B

X Coordinate: -121.24877

Y Coordinate: 38.71618

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (3.1% to 4.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (3.1% to 4.0%)

As Built Desc: 3.8% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 3 Hindrance Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5123B

Location: Conover Dr and Conover Ct - Corner B

X Coordinate: -121.24877

Y Coordinate: 38.71618

Barrier Area: Curb Ramps

Barrier Type: Running Slope - Existing (9.5% or more)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.1



As Built Meas: 1 Quantity: EACH

Description: Ramp run cross slope exceeds 2.0% (9.5% or more)

As Built Desc: 11.1% running slope

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5123C

Location: Conover Dr and Conover Ct - Corner B

X Coordinate: -121.24877

Y Coordinate: 38.71618

Barrier Area: Curb Ramps

Barrier Type: Parallel Ramp Landing - Existing (>5.0% or more)

Code Ref: CBC 1127B.5.4 and ADA/ABA 406.4



As Built Meas: 1 Quantity: EACH

Description: Curb ramp landing or pan not level (>5.0% or more)

As Built Desc: 5.6% landing slope

Solution: Demolish existing and construct new transition

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5123D

Location: Conover Dr and Conover Ct - Corner B

X Coordinate: -121.24877

Y Coordinate: 38.71618

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5124A
Location:	Conover Dr and Conover Ct - Corner C				
X Coordinate:	-121.2487				
Y Coordinate:	38.71598				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (2.1% to 3.0%)		
As Built Desc:	2.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5124B
Location:	Conover Dr and Conover Ct - Corner C				
X Coordinate:	-121.2487				
Y Coordinate:	38.71598				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5125
Location:	Conover Dr - South				
X Coordinate:	-121.24866				
Y Coordinate:	38.71599				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5126
Location:	Conover Dr - North				
X Coordinate:	-121.24846				
Y Coordinate:	38.71619				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5127A
Location:	Conover Dr - East				
X Coordinate:	-121.2488				
Y Coordinate:	38.71627				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	420	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$52,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5127B
Location:	Conover Dr - East				
X Coordinate:	-121.24883				
Y Coordinate:	38.71711				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5128

Location: Conover Dr and Shoemaker Wy - Corner B

X Coordinate: -121.24886

Y Coordinate: 38.71755

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$1,400.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5129A

Location: Conover Dr and Shoemaker Wy - Corner C

X Coordinate: -121.24883

Y Coordinate: 38.71743

Barrier Area: Curb Ramps

Barrier Type: 12" Grooves - Existing (>5.0%)

Code Ref: CBC 1127B.5.6



As Built Meas: 1 Quantity: EACH

Description: 12" grooves at top of curb ramp are not level (>5.0%)

As Built Desc: 7.1% at 12" grooves

Solution: Demolish existing and construct new curb ramp

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5129B
Location:	Conover Dr and Shoemaker Wy - Corner C				
X Coordinate:	-121.24883				
Y Coordinate:	38.71743				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.0% to 9.4%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.0% to 9.4%)		
As Built Desc:	9.2% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5129C
Location:	Conover Dr and Shoemaker Wy - Corner C				
X Coordinate:	-121.24883				
Y Coordinate:	38.71743				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (>5.0% or more)		
As Built Desc:	5.1% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5129D
Location:	Conover Dr and Shoemaker Wy - Corner C				
X Coordinate:	-121.24883				
Y Coordinate:	38.71743				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5130
Location:	Shoemaker Wy - South				
X Coordinate:	-121.24875				
Y Coordinate:	38.71744				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	360	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5131
Location:	Shoemaker Wy - North				
X Coordinate:	-121.24759				
Y Coordinate:	38.71753				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	360	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$45,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5132A
Location:	Conover Dr - East				
X Coordinate:	-121.24885				
Y Coordinate:	38.71759				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	265	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$33,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5132B

Location: Conover Dr - East

X Coordinate: -121.24886

Y Coordinate: 38.71818

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 12 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$1,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5133

Location: Conover Dr - North

X Coordinate: -121.24887

Y Coordinate: 38.71836

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 190 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$23,750.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5134
Location:	Conover Dr - North				
X Coordinate:	-121.25136				
Y Coordinate:	38.7184				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	95	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.6% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$11,875.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5135
Location:	Edgecliff Ct - North				
X Coordinate:	-121.25185				
Y Coordinate:	38.71843				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	480	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.2% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$60,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5136
Location:	Edgecliff Ct - South				
X Coordinate:	-121.25337				
Y Coordinate:	38.71831				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	495	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$61,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5137A
Location:	Edgecliff Ct and Newbridge Wy - Corner C				
X Coordinate:	-121.25163				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (>5.0%)		
As Built Desc:	5.0% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5137B
Location:	Edgecliff Ct and Newbridge Wy - Corner C				
X Coordinate:	-121.25163				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (8.6% to 8.9%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (8.6% to 8.9%)		
As Built Desc:	8.8% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two -way intersection corners C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5137C
Location:	Edgecliff Ct and Newbridge Wy - Corner C				
X Coordinate:	-121.25163				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	Parallel Ramp Landing - Existing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp landing or pan not level (>5.0% or more)		
As Built Desc:	6.4% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two -way intersection corners C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5137D
Location:	Edgecliff Ct and Newbridge Wy - Corner C				
X Coordinate:	-121.25163				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at curb ramp				
As Built Desc:	No detectable warnings at curb ramp				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two -way intersection corners C,D				

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5138A
Location:	Edgecliff Ct and Newbridge Wy - Corner D				
X Coordinate:	-121.25177				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH		
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)				
As Built Desc:	3.8% at 12" grooves				
Solution:	Demolish existing and construct new curb ramp				
Bar. Severity:	3 Hindrance	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two -way intersection corners C,D				

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5138B
Location:	Edgecliff Ct and Newbridge Wy - Corner D				
X Coordinate:	-121.25177				
Y Coordinate:	38.71828				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5139
Location:	Conover Dr - South				
X Coordinate:	-121.25158				
Y Coordinate:	38.71832				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	440	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$55,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5140A
Location:	Conover Dr and Northvale Wy - Corner C				
X Coordinate:	-121.24982				
Y Coordinate:	38.71826				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.1% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two -way intersection corners C,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5140B
Location:	Conover Dr and Northvale Wy - Corner C				
X Coordinate:	-121.24982				
Y Coordinate:	38.71826				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two -way intersection corners C,D

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5141

Location: Conover Dr and Northvale Wy - Corner D

X Coordinate: -121.24998

Y Coordinate: 38.71827

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$1,400.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two -way intersection corners C,D

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5142

Location: Conover Dr - South

X Coordinate: -121.24979

Y Coordinate: 38.7183

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 220 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$27,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5143
Location:	Conover Dr - West				
X Coordinate:	-121.24895				
Y Coordinate:	38.71824				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	874	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$109,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5144
Location:	Conover Dr and Newbridge Wy - Corner A				
X Coordinate:	-121.2489				
Y Coordinate:	38.71583				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5145
Location:	Conover Dr and Newbridge Wy - Corner D				
X Coordinate:	-121.24882				
Y Coordinate:	38.71568				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5146
Location:	Newbridge Wy - North				
X Coordinate:	-121.24896				
Y Coordinate:	38.71581				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	270	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$33,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5147
Location:	Newbridge Wy and Northvale Wy - Corner A				
X Coordinate:	-121.25009				
Y Coordinate:	38.71593				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	15.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5148
Location:	Newbridge Wy and Northvale Wy - Corner B				
X Coordinate:	-121.24992				
Y Coordinate:	38.7159				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5149A
Location:	Northvale Wy - East				
X Coordinate:	-121.24992				
Y Coordinate:	38.71595				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	500	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$62,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5149B
Location:	Northvale Wy - East				
X Coordinate:	-121.24986				
Y Coordinate:	38.71717				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	6	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5150
Location:	Northvale Wy - East				
X Coordinate:	-121.24987				
Y Coordinate:	38.7175				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	278	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$34,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5151
Location:	Northvale Wy - West				
X Coordinate:	-121.24995				
Y Coordinate:	38.7182				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	845	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$105,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5152
Location:	Newbridge Wy - South				
X Coordinate:	-121.25017				
Y Coordinate:	38.71593				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	170	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$21,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5153
Location:	Newbridge Wy - East				
X Coordinate:	-121.25081				
Y Coordinate:	38.7161				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$57,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5154
Location:	Newbridge Wy and Newbridge Ct - Corner B				
X Coordinate:	-121.25119				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5155
Location:	Newbridge Wy and Newbridge Ct - Corner C				
X Coordinate:	-121.2511				
Y Coordinate:	38.71738				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5156
Location:	Newbridge Ct - South				
X Coordinate:	-121.25105				
Y Coordinate:	38.71741				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$18,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5157A
Location:	Newbridge Ct - North				
X Coordinate:	-121.25089				
Y Coordinate:	38.71767				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5157B
Location:	Newbridge Ct - North				
X Coordinate:	-121.25109				
Y Coordinate:	38.71756				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5158
Location:	Newbridge Wy - East				
X Coordinate:	-121.25124				
Y Coordinate:	38.71747				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	320	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5159
Location:	Newbridge Wy - West				
X Coordinate:	-121.25175				
Y Coordinate:	38.71825				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	540	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$67,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5160
Location:	Newbridge Wy and Newbridge Ct - Corner A				
X Coordinate:	-121.25097				
Y Coordinate:	38.71689				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5161
Location:	Newbridge Wy and Newbridge Ct - Corner D				
X Coordinate:	-121.25091				
Y Coordinate:	38.71665				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5162A
Location:	Newbridge Ct - North				
X Coordinate:	-121.25102				
Y Coordinate:	38.71688				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5162B
Location:	Newbridge Ct - North				
X Coordinate:	-121.25109				
Y Coordinate:	38.71685				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	0" clearance at tree branches		
Solution:	Remove object or provide detectable warning		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5163
Location:	Newbridge Ct - South				
X Coordinate:	-121.25121				
Y Coordinate:	38.71671				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5164
Location:	Newbridge Wy - West				
X Coordinate:	-121.2509				
Y Coordinate:	38.71662				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$25,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5165
Location:	Newbridge Wy - South				
X Coordinate:	-121.25089				
Y Coordinate:	38.71597				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	610	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$76,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5166
Location:	Newbridge Wy - West				
X Coordinate:	-121.24877				
Y Coordinate:	38.71569				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	345	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5167
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24858				
Y Coordinate:	38.71453				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5168

Location: Old Auburn Rd - North

X Coordinate: -121.24868

Y Coordinate: 38.71448

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 71 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$8,875.00

Status:

Implementation Priority: 1

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5169

Location: Old Auburn Rd and Robert Creek Ct - Corner A

X Coordinate: -121.24903

Y Coordinate: 38.71434

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.5% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 1

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5170

Location: Old Auburn Rd and Robert Creek Ct - Corner B

X Coordinate: -121.24888

Y Coordinate: 38.71437

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 15.9% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/7/2011 Report Date: 2/7/2011 Barrier #: 5171

Location: Robert Creek Ct - East

X Coordinate: -121.24896

Y Coordinate: 38.7144

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 290 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$36,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5172
Location:	Robert Creek Ct - West				
X Coordinate:	-121.24952				
Y Coordinate:	38.71503				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	323	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5173
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24914				
Y Coordinate:	38.71422				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	188	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$18,800.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5174
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24966				
Y Coordinate:	38.71394				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	63	Quantity:	LF
Description:	No pedestrian route provided within shoulder or sidewalk area		
As Built Desc:	No pedestrian route provided at sidewalk or shoulder		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,300.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5175
Location:	Old Auburn Rd - North				
X Coordinate:	-121.24986				
Y Coordinate:	38.71382				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	244	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5176
Location:	Orelle Creek Ct - East				
X Coordinate:	-121.25066				
Y Coordinate:	38.71353				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	55	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5177
Location:	Old Auburn Rd and Orelle Creek Ct - Corner A				
X Coordinate:	-121.25088				
Y Coordinate:	38.71361				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	15.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5178
Location:	Old Auburn Rd and Orelle Creek Ct - Corner B				
X Coordinate:	-121.25076				
Y Coordinate:	38.71365				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5179
Location:	Orelle Creek Ct - East				
X Coordinate:	-121.25079				
Y Coordinate:	38.71366				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5180
Location:	Orelle Creek Ct and Allene Creek Ct - Corner B				
X Coordinate:	-121.25088				
Y Coordinate:	38.71423				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	15.6% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5181
Location:	Orelle Creek Ct and Allene Creek Ct - Corner C				
X Coordinate:	-121.25089				
Y Coordinate:	38.71413				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	15.2% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5182
Location:	Allene Creek Ct - South				
X Coordinate:	-121.25085				
Y Coordinate:	38.71414				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.1% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$18,750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5183
Location:	Allene Creek Ct - North				
X Coordinate:	-121.2505				
Y Coordinate:	38.71426				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$18,750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5184
Location:	Orelle Creek Ct - East				
X Coordinate:	-121.25091				
Y Coordinate:	38.71427				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	320	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5185
Location:	Orelle Creek Ct - West				
X Coordinate:	-121.25099				
Y Coordinate:	38.71505				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	540	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$67,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5186
Location:	Orelle Creek Ct - West				
X Coordinate:	-121.2509				
Y Coordinate:	38.71356				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	55	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/7/2011	Report Date:	2/7/2011	Barrier #:	5187
Location:	Old Auburn Rd - North				
X Coordinate:	-121.25087				
Y Coordinate:	38.71337				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	313	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$31,300.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5188

Location: Canyon Oak Dr - East

X Coordinate: -121.25188

Y Coordinate: 38.71299

Barrier Area: Sidewalks

Barrier Type: No sidewalk

Code Ref: CBC 1127B.1 and ADA/ABA 206.2.1



As Built Meas: 52 Quantity: LF

Description: No pedestrian route provided

As Built Desc: No sidewalk provided

Solution: Construct new firm and stable pedestrian route

Bar. Severity: 1 Necessary Cost Estimate: \$5,200.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5189

Location: Canyon Oak Dr and Old Auburn Rd - Corner A

X Coordinate: -121.2521

Y Coordinate: 38.71298

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No curb cut at corner (intersection)

As Built Desc: No curb ramp at corner

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5190

Location: Canyon Oak Dr and Old Auburn Rd - Corner B

X Coordinate: -121.25196

Y Coordinate: 38.71307

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.3% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5191

Location: Canyon Oak Dr - East

X Coordinate: -121.25202

Y Coordinate: 38.71308

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 176 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$22,000.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5192

Location: Canyon Oak Dr and Canyon Oak Ct - Corner B

X Coordinate: -121.25211

Y Coordinate: 38.71366

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.9% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5193

Location: Canyon Oak Dr and Canyon Oak Ct - Corner C

X Coordinate: -121.25212

Y Coordinate: 38.7136

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 13.5% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5194
Location:	Canyon Oak Ct - South				
X Coordinate:	-121.25209				
Y Coordinate:	38.71358				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	110	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$13,750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5195A
Location:	Canyon Oak Ct - North				
X Coordinate:	-121.25174				
Y Coordinate:	38.71361				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	13	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5195B
Location:	Canyon Oak Ct - North				
X Coordinate:	-121.25178				
Y Coordinate:	38.71371				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5196
Location:	Canyon Oak Dr - East				
X Coordinate:	-121.25214				
Y Coordinate:	38.7137				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	597	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$74,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5197A
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25184				
Y Coordinate:	38.71529				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	379	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$47,375.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5197B
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25226				
Y Coordinate:	38.71523				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5198

Location: Canyon Oak Dr and Cripple Oak Ct - Corner A

X Coordinate: -121.25334

Y Coordinate: 38.71496

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.4% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5199

Location: Canyon Oak Dr and Cripple Oak Ct - Corner B

X Coordinate: -121.25318

Y Coordinate: 38.71494

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.7% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5200A
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.2532				
Y Coordinate:	38.71502				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	502	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$62,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5200B
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.25319				
Y Coordinate:	38.71544				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip due to tree heaves		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5201
Location:	Cripple Oak Ct and Cripple Oak Ct - Corner B				
X Coordinate:	-121.25321				
Y Coordinate:	38.71582				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5202
Location:	Cripple Oak Ct and Cripple Oak Ct - Corner C				
X Coordinate:	-121.2532				
Y Coordinate:	38.71572				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5203A
Location:	Cripple Oak Ct - South				
X Coordinate:	-121.25316				
Y Coordinate:	38.71576				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	160	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$20,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5203B
Location:	Cripple Oak Ct - South				
X Coordinate:	-121.25277				
Y Coordinate:	38.71568				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	6	Quantity:	LF		
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)				
As Built Desc:	Cracked concrete				
Solution:	Repair surface to make firm and stable				
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5204A
Location:	Cripple Oak Ct - North				
X Coordinate:	-121.25276				
Y Coordinate:	38.71584				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	153	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$19,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5204B
Location:	Cripple Oak Ct - North				
X Coordinate:	-121.25295				
Y Coordinate:	38.71588				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5205A
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.2532				
Y Coordinate:	38.71588				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	300	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	6.2% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$37,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5205B
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.25321				
Y Coordinate:	38.716				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip due to tree heaves				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5205C
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.25321				
Y Coordinate:	38.71653				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF		
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)				
As Built Desc:	Cracked concrete				
Solution:	Repair surface to make firm and stable				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5205D
Location:	Cripple Oak Ct - East				
X Coordinate:	-121.25311				
Y Coordinate:	38.71688				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	76	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5206
Location:	Cripple Oak Ct - West				
X Coordinate:	-121.25333				
Y Coordinate:	38.71699				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	749	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$93,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5207
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25336				
Y Coordinate:	38.71496				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	216	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$27,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5208
Location:	Canyon Oak Dr and Moss Oak Ave - Corner A				
X Coordinate:	-121.25437				
Y Coordinate:	38.71497				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5209
Location:	Canyon Oak Dr and Moss Oak Ave - Corner B				
X Coordinate:	-121.25418				
Y Coordinate:	38.71495				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5210A
Location:	Moss Oak Ave - East				
X Coordinate:	-121.25421				
Y Coordinate:	38.71531				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	514	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$64,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5210B
Location:	Moss Oak Ave - East				
X Coordinate:	-121.2542				
Y Coordinate:	38.71595				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5211
Location:	Moss Oak Ave - North				
X Coordinate:	-121.25522				
Y Coordinate:	38.7174				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	282	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$35,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5212
Location:	Moss Oak Ave and Crestmont Ave - Corner B				
X Coordinate:	-121.25757				
Y Coordinate:	38.71742				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5213
Location:	Moss Oak Ave and Crestmont Ave - Corner C				
X Coordinate:	-121.2576				
Y Coordinate:	38.7173				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5214
Location:	Moss Oak Ave - South				
X Coordinate:	-121.25758				
Y Coordinate:	38.71728				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	169	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$21,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5215
Location:	Moss Oak Ave - South				
X Coordinate:	-121.2569				
Y Coordinate:	38.71725				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	579	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$72,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5216
Location:	Moss Oak Ave - West				
X Coordinate:	-121.25484				
Y Coordinate:	38.7172				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	294	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$36,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5217

Location: Moss Oak Ave and Coast Oak Wy - Corner A

X Coordinate: -121.25442

Y Coordinate: 38.7165

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5218

Location: Moss Oak Ave and Coast Oak Wy - Corner D

X Coordinate: -121.25443

Y Coordinate: 38.71642

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 7.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5219
Location:	Moss Oak Ave - West				
X Coordinate:	-121.25437				
Y Coordinate:	38.71629				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	210	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5220
Location:	Moss Oak Ave and Blue Oak Wy - Corner A				
X Coordinate:	-121.25436				
Y Coordinate:	38.71566				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5221
Location:	Moss Oak Ave and Blue Oak Wy - Corner D				
X Coordinate:	-121.25441				
Y Coordinate:	38.71553				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5222
Location:	Moss Oak Ave - West				
X Coordinate:	-121.25438				
Y Coordinate:	38.71551				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	178	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.9% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5223
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25458				
Y Coordinate:	38.71495				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	167	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.2% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$20,875.00	Status:
Implementation Priority:	3	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5224
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25615				
Y Coordinate:	38.71495				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	438	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.6% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$54,750.00	Status:
Implementation Priority:	3	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5225
Location:	Canyon Oak Dr and Twin Oaks Ave - A				
X Coordinate:	-121.25753				
Y Coordinate:	38.71495				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5226
Location:	Canyon Oak Dr and Twin Oaks Ave - B				
X Coordinate:	-121.25729				
Y Coordinate:	38.71492				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5227
Location:	Canyon Oak Dr and Twin Oaks Ave - C				
X Coordinate:	-121.25723				
Y Coordinate:	38.71481				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.0% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5228
Location:	Canyon Oak Dr and Twin Oaks Ave - D				
X Coordinate:	-121.25747				
Y Coordinate:	38.71482				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.8% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5229
Location:	Canyon Oak Dr - South				
X Coordinate:	-121.25717				
Y Coordinate:	38.71482				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	159	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$19,875.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5230
Location:	Canyon Oak Dr - South				
X Coordinate:	-121.25198				
Y Coordinate:	38.71517				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	9.9% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5231

Location: Canyon Oak Dr - West

X Coordinate: -121.25195

Y Coordinate: 38.71517

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 271 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.8% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$33,875.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5232

Location: Canyon Oak Dr and Canyon Oak Ct - Corner A

X Coordinate: -121.25201

Y Coordinate: 38.71441

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.2% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5233

Location: Canyon Oak Dr and Canyon Oak Ct - Corner D

X Coordinate: -121.2521

Y Coordinate: 38.71422

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.2% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5234

Location: Canyon Oak Ct - North

X Coordinate: -121.2521

Y Coordinate: 38.71445

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 87 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$10,875.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5235
Location:	Canyon Oak Ct - South				
X Coordinate:	-121.25231				
Y Coordinate:	38.7143				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	81	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5236A
Location:	Canyon Oak Ave - West				
X Coordinate:	-121.2521				
Y Coordinate:	38.71419				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	317	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$39,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5236B
Location:	Canyon Oak Ave - West				
X Coordinate:	-121.25209				
Y Coordinate:	38.71419				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5237
Location:	Canyon Oak Dr and Glen Canyon Ct - Corner A				
X Coordinate:	-121.2523				
Y Coordinate:	38.71334				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	14.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5238

Location: Canyon Oak Dr and Glen Canyon Ct - Corner D

X Coordinate: -121.25226

Y Coordinate: 38.71325

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 10.1% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 3 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5239

Location: Glen Canyon Ct - North

X Coordinate: -121.25233

Y Coordinate: 38.71334

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 340 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$42,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5240
Location:	Glen Canyon Ct - East				
X Coordinate:	-121.25315				
Y Coordinate:	38.71318				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	383	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$47,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5241
Location:	Glen Canyon Ct - West				
X Coordinate:	-121.25329				
Y Coordinate:	38.71417				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	446	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$55,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5242A
Location:	Glen Canyon Ct - South				
X Coordinate:	-121.25311				
Y Coordinate:	38.71308				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	248	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$31,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5242B
Location:	Glen Canyon Ct - South				
X Coordinate:	-121.25296				
Y Coordinate:	38.71304				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5243
Location:	Canyon Oak Dr - West				
X Coordinate:	-121.25227				
Y Coordinate:	38.71325				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$9,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5244
Location:	Canyon Oak Dr - West				
X Coordinate:	-121.25208				
Y Coordinate:	38.71295				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	58	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,800.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5245
Location:	Old Auburn Rd - North				
X Coordinate:	-121.25203				
Y Coordinate:	38.71283				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	466	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$46,600.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5246A
Location:	Old Auburn Rd - North				
X Coordinate:	-121.25337				
Y Coordinate:	38.71218				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	266	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$33,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5246B
Location:	Old Auburn Rd - North				
X Coordinate:	-121.2534				
Y Coordinate:	38.71216				
Barrier Area:	Sidewalks				
Barrier Type:	Drop-off Along Ped Route (> 4")				
Code Ref:	CBC 1133B.8.1				



As Built Meas:	180	Quantity:	LF
Description:	Drop of more than 4" along pedestrian route lacks warning curb		
As Built Desc:	48" drop off creates hazardous condition for the visually impaired		
Solution:	Provide curb projecting at least 6" above the walk or sidewalk surface to warn the blind of a potent		
Bar. Severity:	1 Necessary	Cost Estimate:	\$31,500.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5247
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25443				
Y Coordinate:	38.71198				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	77	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$9,625.00
Status:			
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5248

Location: Twin Oaks Ave and Holly Oak Ct - Corner A

X Coordinate: -121.25481

Y Coordinate: 38.71216

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5249

Location: Twin Oaks Ave and Holly Oak Ct - Corner B

X Coordinate: -121.25463

Y Coordinate: 38.71225

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.9% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5250

Location: Twin Oaks Ave and Holly Oak Ct - Corner C

X Coordinate: -121.25458

Y Coordinate: 38.71214

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 13.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5251

Location: Twin Oaks Ave and Holly Oak Ct - Corner D

X Coordinate: -121.2547

Y Coordinate: 38.71206

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 13.7% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary

Cost Estimate: \$2,500.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5252
Location:	Holly Oak Ct - South				
X Coordinate:	-121.25454				
Y Coordinate:	38.7122				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	195	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5253
Location:	Holly Oak Ct - North				
X Coordinate:	-121.25418				
Y Coordinate:	38.71251				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	188	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5254
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25469				
Y Coordinate:	38.71229				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	292	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$36,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5255
Location:	Twin Oaks Ave and Scarlet Oak Cir - Corner B				
X Coordinate:	-121.25517				
Y Coordinate:	38.71287				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5256
Location:	Twin Oaks Ave and Scarlet Oak Cir - Corner C				
X Coordinate:	-121.25509				
Y Coordinate:	38.71275				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5257A
Location:	Scarlet Oak Cir - South				
X Coordinate:	-121.25504				
Y Coordinate:	38.71278				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	364	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5257B
Location:	Scarlet Oak Cir - South				
X Coordinate:	-121.25494				
Y Coordinate:	38.71284				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5257C
Location:	Scarlet Oak Cir - South				
X Coordinate:	-121.25412				
Y Coordinate:	38.71322				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5258

Location: Scarlet Oak Cir - East

X Coordinate: -121.25415

Y Coordinate: 38.71331

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 338 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$42,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/10/2011 Report Date: 2/10/2011 Barrier #: 5259

Location: Scarlet Oak Cir - North

X Coordinate: -121.25417

Y Coordinate: 38.71426

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 279 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$34,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5260
Location:	Scarlet Oak Cir - West				
X Coordinate:	-121.2551				
Y Coordinate:	38.71427				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	353	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.3% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$44,125.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5261
Location:	Scarlet Oak Cir and Twin Oaks Ave - Corner B				
X Coordinate:	-121.2556				
Y Coordinate:	38.71345				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	12.3% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5262
Location:	Scarlet Oak Cir and Twin Oaks Ave - Corner C				
X Coordinate:	-121.25553				
Y Coordinate:	38.71336				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5263
Location:	Scarlet Oak Cir - East				
X Coordinate:	-121.25549				
Y Coordinate:	38.7134				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	317	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$39,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5264
Location:	Scarlet Oak Cir - South				
X Coordinate:	-121.25492				
Y Coordinate:	38.71413				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5265
Location:	Scarlet Oak Cir - South				
X Coordinate:	-121.25427				
Y Coordinate:	38.71412				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	11.9% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5266
Location:	Scarlet Oak Cir - West				
X Coordinate:	-121.2542				
Y Coordinate:	38.71411				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	348	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$43,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5267
Location:	Scarlet Oak Cir - North				
X Coordinate:	-121.25444				
Y Coordinate:	38.71322				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	232	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$29,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5268
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25519				
Y Coordinate:	38.71291				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	175	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$21,875.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5269
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25575				
Y Coordinate:	38.71352				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	236	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$29,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5270
Location:	Twin Oaks Ave and Twin Oaks Ave Ct - Corner B				
X Coordinate:	-121.25636				
Y Coordinate:	38.71387				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	11.0% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5271
Location:	Twin Oaks Ave and Twin Oaks Ave Ct - Corner C				
X Coordinate:	-121.25622				
Y Coordinate:	38.7138				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	14.4% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5272
Location:	Twin Oaks Ave Ct - South				
X Coordinate:	-121.25619				
Y Coordinate:	38.71386				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	171	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$21,375.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5273
Location:	Twin Oaks Ave Ct - North				
X Coordinate:	-121.25597				
Y Coordinate:	38.71426				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	163	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$20,375.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5274
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25642				
Y Coordinate:	38.7139				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	325	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,625.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5275
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25739				
Y Coordinate:	38.71504				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	432	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$54,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5276
Location:	Twin Oaks Ave and Coast Oak Wy - Corner B				
X Coordinate:	-121.25794				
Y Coordinate:	38.71626				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5277
Location:	Twin Oaks Ave and Coast Oak Wy - Corner C				
X Coordinate:	-121.25789				
Y Coordinate:	38.71617				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5278A
Location:	Coast Oak Wy - South				
X Coordinate:	-121.25763				
Y Coordinate:	38.71626				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	211	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.6% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$26,375.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5278B
Location:	Coast Oak Wy - South				
X Coordinate:	-121.25744				
Y Coordinate:	38.7163				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip due to tree heaves				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5279
Location:	Coast Oak Wy and Blue Oak Wy - Corner C				
X Coordinate:	-121.25676				
Y Coordinate:	38.71633				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5280
Location:	Coast Oak Wy and Blue Oak Wy - Corner D				
X Coordinate:	-121.25688				
Y Coordinate:	38.7163				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5281
Location:	Blue Oak Wy - West				
X Coordinate:	-121.25691				
Y Coordinate:	38.71626				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	279	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$34,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5282A
Location:	Blue Oak Wy - South				
X Coordinate:	-121.25655				
Y Coordinate:	38.71554				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	607	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$75,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5282B
Location:	Blue Oak Wy - South				
X Coordinate:	-121.25557				
Y Coordinate:	38.71552				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5283A
Location:	Blue Oak Wy - North				
X Coordinate:	-121.25483				
Y Coordinate:	38.71564				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$57,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5283B
Location:	Blue Oak Wy - North				
X Coordinate:	-121.25594				
Y Coordinate:	38.71563				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	28" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5284
Location:	Blue Oak Wy - North				
X Coordinate:	-121.25648				
Y Coordinate:	38.71565				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	9.6% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5285A
Location:	Blue Oak Wy - East				
X Coordinate:	-121.25654				
Y Coordinate:	38.71571				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	230	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$28,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5285B
Location:	Blue Oak Wy - East				
X Coordinate:	-121.2567				
Y Coordinate:	38.7163				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	26" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5286
Location:	Coast Oak Wy - South				
X Coordinate:	-121.25641				
Y Coordinate:	38.71638				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	551	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$68,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5287
Location:	Coast Oak Wy - North				
X Coordinate:	-121.25449				
Y Coordinate:	38.71645				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	125	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.0% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5288
Location:	Coast Oak Wy - North				
X Coordinate:	-121.25692				
Y Coordinate:	38.71639				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	304	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.1% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$38,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/10/2011	Report Date:	2/10/2011	Barrier #:	5289
Location:	Twin Oaks Ave - East				
X Coordinate:	-121.25809				
Y Coordinate:	38.7164				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	139	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$17,375.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5290
Location:	Twin Oaks Ave and Crestmont Ave - Corner A				
X Coordinate:	-121.25833				
Y Coordinate:	38.71709				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.3% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,D				
--------	------------------------------------	--	--	--	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5291
Location:	Twin Oaks Ave and Crestmont Ave - Corner D				
X Coordinate:	-121.25829				
Y Coordinate:	38.71699				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.4% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,D				
--------	------------------------------------	--	--	--	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5292
Location:	Crestmont Ave - East				
X Coordinate:	-121.25829				
Y Coordinate:	38.71692				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	230	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.1% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$28,750.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5293
Location:	Crestmont Ave - East				
X Coordinate:	-121.25827				
Y Coordinate:	38.71687				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	112	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.6% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$14,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5294
Location:	Crestmont Ave and Bonnie Oak Wy - Corner A				
X Coordinate:	-121.25772				
Y Coordinate:	38.71897				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5295
Location:	Crestmont Ave and Bonnie Oak Wy - Corner B				
X Coordinate:	-121.25756				
Y Coordinate:	38.71896				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5296

Location: Crestmont Ave and Bonnie Oak Wy - Corner C

X Coordinate: -121.25761

Y Coordinate: 38.71875

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.8% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5297

Location: Crestmont Ave and Bonnie Oak Wy - Corner D

X Coordinate: -121.25781

Y Coordinate: 38.71882

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.2% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5298
Location:	Bonnie Oak Wy - South				
X Coordinate:	-121.25754				
Y Coordinate:	38.71878				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	888	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$111,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5299
Location:	Bonnie Oak Wy and Oriol Oak Ct - Corner A				
X Coordinate:	-121.25437				
Y Coordinate:	38.71869				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5300
Location:	Bonnie Oak Wy and Oriol Oak Ct - Corner D				
X Coordinate:	-121.25436				
Y Coordinate:	38.71859				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	7.9% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two - way intersection corners A,D				

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5301
Location:	Oriol Oak Ct - West				
X Coordinate:	-121.25433				
Y Coordinate:	38.71846				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	146	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.6% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$18,250.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5302
Location:	Oriol Oak Ct - East				
X Coordinate:	-121.25435				
Y Coordinate:	38.71817				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	117	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$14,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5303
Location:	Oriol Oak Ct - East				
X Coordinate:	-121.25426				
Y Coordinate:	38.71861				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	126	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$15,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5304
Location:	Oriol Oak Ct - West				
X Coordinate:	-121.2543				
Y Coordinate:	38.71902				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	114	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$14,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5305
Location:	Bonnie Oak Wy - West				
X Coordinate:	-121.25437				
Y Coordinate:	38.71873				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	465	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$58,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5306
Location:	Bonnie Oak Wy - West				
X Coordinate:	-121.25629				
Y Coordinate:	38.71887				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	338	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.8% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$42,250.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5307
Location:	Crestmont Ave - East				
X Coordinate:	-121.25755				
Y Coordinate:	38.71914				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	60	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.1% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$7,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5308
Location:	Crestmont Ave - West				
X Coordinate:	-121.25756				
Y Coordinate:	38.71932				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5309A
Location:	Bonnie Oak Wy - North				
X Coordinate:	-121.25766				
Y Coordinate:	38.71895				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	744	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$93,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5309B
Location:	Bonnie Oak Wy - North				
X Coordinate:	-121.26051				
Y Coordinate:	38.71912				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5310
Location:	Bonnie Oak Wy - North				
X Coordinate:	-121.26061				
Y Coordinate:	38.71911				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	8.5% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5311
Location:	Bonnie Oak Wy - East				
X Coordinate:	-121.26061				
Y Coordinate:	38.71915				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	113	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$14,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5312
Location:	Bonnie Oak Wy - West				
X Coordinate:	-121.26079				
Y Coordinate:	38.71946				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	120	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$15,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5313
Location:	Bonnie Oak Wy - South				
X Coordinate:	-121.26097				
Y Coordinate:	38.71903				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	825	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$103,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5314
Location:	Crestmont Ave - West				
X Coordinate:	-121.2578				
Y Coordinate:	38.71879				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	720	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$90,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5315
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.25836				
Y Coordinate:	38.71711				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	160	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$20,000.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5316
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.25942				
Y Coordinate:	38.71782				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	980	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$122,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5317
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26241				
Y Coordinate:	38.71876				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5318
Location:	Twin Oaks Ave - South				
X Coordinate:	-121.26242				
Y Coordinate:	38.71854				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	170	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$21,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5319
Location:	Twin Oaks Ave and Gary Oak Dr - Corner C				
X Coordinate:	-121.26179				
Y Coordinate:	38.71844				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	7.7% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two -way intersection corners C,D				
--------	-----------------------------------	--	--	--	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5320
Location:	Twin Oaks Ave and Gary Oak Dr - Corner D				
X Coordinate:	-121.2619				
Y Coordinate:	38.71851				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	9.8% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two -way intersection corners C,D				
--------	-----------------------------------	--	--	--	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5321
Location:	Twin Oaks Ave - South				
X Coordinate:	-121.26167				
Y Coordinate:	38.7185				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1070	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$133,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5322A
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25848				
Y Coordinate:	38.71706				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	553	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$69,125.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5322B
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25791				
Y Coordinate:	38.71595				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5323
Location:	Twin Oaks Ave and Lobata St - Corner A				
X Coordinate:	-121.25783				
Y Coordinate:	38.7156				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5324
Location:	Twin Oaks Ave and Lobata St - Corner D				
X Coordinate:	-121.25782				
Y Coordinate:	38.71549				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5325
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25775				
Y Coordinate:	38.71546				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	170	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$21,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5326A
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25737				
Y Coordinate:	38.71475				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	700	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$87,500.00	Status:
Implementation Priority:	2	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5326B
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25693				
Y Coordinate:	38.7142				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF	
Description:	Change in level greater than 1/2"			
As Built Desc:	1/2" lip in sidewalk surface due to tree heave			
Solution:	Grind or repair sidewalk to remove trip hazard			
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:
Implementation Priority:	2	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5327
Location:	Twin Oaks Ave and Alba Ct - Corner A				
X Coordinate:	-121.25579				
Y Coordinate:	38.71334				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	14.1% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two - way intersection corners A,D				

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5328
Location:	Twin Oaks Ave and Alba Ct - Corner D				
X Coordinate:	-121.25568				
Y Coordinate:	38.71325				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.2% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two - way intersection corners A,D				

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5329A
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25564				
Y Coordinate:	38.71324				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	430	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$53,750.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5329B
Location:	Twin Oaks Ave - West				
X Coordinate:	-121.25481				
Y Coordinate:	38.71238				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	20	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5330

Location: Twin Oaks Ave - West

X Coordinate: -121.25463

Y Coordinate: 38.71212

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 80 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended

Cost Estimate: \$10,000.00

Status:

Implementation Priority: 2

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5331

Location: Old Auburn Blvd - North

X Coordinate: -121.25442

Y Coordinate: 38.71168

Barrier Area: Sidewalks

Barrier Type: No Sidewalk - No Barricade

Code Ref: MUTCD Section 6D.01



As Built Meas: 1 Quantity: JOB

Description: No barricade provided where sidewalk ends in hazardous location

As Built Desc: No barricade or other warning provided for the visually impaired at end of sidewalk

Solution: Provide barricade with cane detectable warning at end of sidewalk

Bar. Severity: 1 Necessary

Cost Estimate: \$1,350.00

Status:

Implementation Priority: 1

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5332A
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.25447				
Y Coordinate:	38.71162				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	256	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$32,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	High speed traffic		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5332B
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.25467				
Y Coordinate:	38.71152				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5333
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.25546				
Y Coordinate:	38.71113				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1000	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$100,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5334
Location:	Coral Oak Wy - East				
X Coordinate:	-121.25849				
Y Coordinate:	38.70982				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	50	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5335
Location:	Coral Oak Wy - West				
X Coordinate:	-121.25879				
Y Coordinate:	38.70986				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5336
Location:	Coral Oak Wy - East				
X Coordinate:	-121.25866				
Y Coordinate:	38.70995				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5337
Location:	Coral Oak Wy - East				
X Coordinate:	-121.25866				
Y Coordinate:	38.70998				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5338
Location:	Coral Oak Wy and Holly Oak St - Corner C				
X Coordinate:	-121.25893				
Y Coordinate:	38.71038				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5339
Location:	Coral Oak Wy and Holly Oak St - Corner D				
X Coordinate:	-121.25884				
Y Coordinate:	38.71024				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two -way intersection corners C,D

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5340A
Location:	Holly Oak St - South				
X Coordinate:	-121.25878				
Y Coordinate:	38.71024				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1315	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$164,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5340B
Location:	Holly Oak St - South				
X Coordinate:	-121.25809				
Y Coordinate:	38.71053				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5341
Location:	Holly Oak St - North				
X Coordinate:	-121.25489				
Y Coordinate:	38.7121				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	777	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$97,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5342
Location:	Holly Oak St and Mesa Oak Wy - Corner A				
X Coordinate:	-121.25744				
Y Coordinate:	38.711				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5343
Location:	Holly Oak St and Mesa Oak Wy - Corner B				
X Coordinate:	-121.25731				
Y Coordinate:	38.71105				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5344
Location:	Mesa Oak Wy - East				
X Coordinate:	-121.25733				
Y Coordinate:	38.71106				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	160	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.3% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$20,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5345
Location:	Mesa Oak Wy and Majestic Oak Wy - Corner C				
X Coordinate:	-121.25771				
Y Coordinate:	38.7117				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	8.6% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5346
Location:	Mesa Oak Wy and Majestic Oak Wy - Corner D				
X Coordinate:	-121.25767				
Y Coordinate:	38.71157				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	11.6% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5347
Location:	Mesa Oak Wy - East				
X Coordinate:	-121.25775				
Y Coordinate:	38.71172				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	620	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.0% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$77,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5348A
Location:	Mesa Oak Wy - South				
X Coordinate:	-121.25923				
Y Coordinate:	38.71293				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	585	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$73,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5348B
Location:	Mesa Oak Wy - South				
X Coordinate:	-121.25918				
Y Coordinate:	38.71342				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5349
Location:	Mesa Oak Wy - South				
X Coordinate:	-121.25856				
Y Coordinate:	38.71381				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5350
Location:	Mesa Oak Wy - West				
X Coordinate:	-121.25794				
Y Coordinate:	38.71397				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	546	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$68,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5351
Location:	Mesa Oak Wy and Alba Ct - Corner A				
X Coordinate:	-121.25655				
Y Coordinate:	38.71302				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5352
Location:	Mesa Oak Wy and Alba Ct - Corner B				
X Coordinate:	-121.25639				
Y Coordinate:	38.71304				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5353
Location:	Mesa Oak Wy and Alba Ct - Corner C				
X Coordinate:	-121.25629				
Y Coordinate:	38.71291				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5354
Location:	Mesa Oak Wy and Alba Ct - Corner D				
X Coordinate:	-121.25644				
Y Coordinate:	38.71286				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5355
Location:	Alba Ct - North				
X Coordinate:	-121.25655				
Y Coordinate:	38.71293				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	230	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$28,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5356
Location:	Alba Ct - East				
X Coordinate:	-121.25734				
Y Coordinate:	38.71268				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	360	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5357A
Location:	Alba Ct - West				
X Coordinate:	-121.25832				
Y Coordinate:	38.71326				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	450	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$56,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5357B
Location:	Alba Ct - West				
X Coordinate:	-121.2581				
Y Coordinate:	38.71297				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5358
Location:	Alba Ct - South				
X Coordinate:	-121.25728				
Y Coordinate:	38.71245				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	250	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.5% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$31,250.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5359A
Location:	Majestic Oak Wy - West				
X Coordinate:	-121.25641				
Y Coordinate:	38.71282				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.4% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$23,750.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5359B
Location:	Majestic Oak Wy - West				
X Coordinate:	-121.25637				
Y Coordinate:	38.71279				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5360A
Location:	Majestic Oak Wy - North				
X Coordinate:	-121.25606				
Y Coordinate:	38.7123				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	520	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$65,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5360B
Location:	Majestic Oak Wy - North				
X Coordinate:	-121.25652				
Y Coordinate:	38.71211				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5361A
Location:	Majestic Oak Wy - South				
X Coordinate:	-121.25761				
Y Coordinate:	38.71157				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	560	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$70,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5361B
Location:	Majestic Oak Wy - South				
X Coordinate:	-121.25652				
Y Coordinate:	38.71203				
Barrier Area:	Sidewalks				
Barrier Type:	Protruding Hazard				
Code Ref:	CBC 1133B.8.6.1 and ADA/ABA 307.2				



As Built Meas:	1	Quantity:	JOB
Description:	Protruding object in route of travel between 27" and 80" high		
As Built Desc:	44" at tree branches		
Solution:	Trim trees to provide min. 48"		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5362
Location:	Majestic Oak Wy - East				
X Coordinate:	-121.25588				
Y Coordinate:	38.71231				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	222	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$27,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5363
Location:	Alba Ct - South				
X Coordinate:	-121.2563				
Y Coordinate:	38.71295				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	184	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5364A
Location:	Alba Ct - North				
X Coordinate:	-121.25584				
Y Coordinate:	38.7133				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	184	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.2% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5364B
Location:	Alba Ct - North				
X Coordinate:	-121.25587				
Y Coordinate:	38.71331				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5365
Location:	Mesa Oak Wy - East				
X Coordinate:	-121.25641				
Y Coordinate:	38.71299				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	544	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$68,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5366A
Location:	Mesa Oak Wy - North				
X Coordinate:	-121.25787				
Y Coordinate:	38.71404				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	460	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$57,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5366B
Location:	Mesa Oak Wy - North				
X Coordinate:	-121.25898				
Y Coordinate:	38.71371				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5367
Location:	Mesa Oak Wy and Robur Wy - Corner A				
X Coordinate:	-121.25932				
Y Coordinate:	38.71341				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.2% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5368
Location:	Mesa Oak Wy and Robur Wy - Corner B				
X Coordinate:	-121.25928				
Y Coordinate:	38.7135				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.2% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5369A
Location:	Mesa Oak Wy - West				
X Coordinate:	-121.25933				
Y Coordinate:	38.71337				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1080	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.7% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$135,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5369B
Location:	Mesa Oak Wy - West				
X Coordinate:	-121.25859				
Y Coordinate:	38.7122				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	6	Quantity:	LF		
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)				
As Built Desc:	Cracked concrete				
Solution:	Repair surface to make firm and stable				
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5370A
Location:	Holly Oak St - North				
X Coordinate:	-121.25747				
Y Coordinate:	38.71094				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	180	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5370B
Location:	Holly Oak St - North				
X Coordinate:	-121.25763				
Y Coordinate:	38.71085				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5371
Location:	Holly Oak St and Canyon Oak Dr - Corner A				
X Coordinate:	-121.25826				
Y Coordinate:	38.71062				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5372
Location:	Holly Oak St and Canyon Oak Dr - Corner B				
X Coordinate:	-121.25808				
Y Coordinate:	38.71067				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5373
Location:	Canyon Oak Dr - East				
X Coordinate:	-121.25814				
Y Coordinate:	38.71071				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1260	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.2% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$157,500.00	Status:
Implementation Priority:	3	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5374
Location:	Canyon Oak Dr and Robur Wy - Corner C				
X Coordinate:	-121.25996				
Y Coordinate:	38.71375				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	7.4% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	3	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5375
Location:	Canyon Oak Dr and Robur Wy - Corner D				
X Coordinate:	-121.26002				
Y Coordinate:	38.71365				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5376A
Location:	Robur Wy - West				
X Coordinate:	-121.25994				
Y Coordinate:	38.71363				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5376B
Location:	Robur Wy - West				
X Coordinate:	-121.25977				
Y Coordinate:	38.71357				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	8	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5377
Location:	Robur Wy - East				
X Coordinate:	-121.25934				
Y Coordinate:	38.71346				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5378
Location:	Canyon Oak Dr - South				
X Coordinate:	-121.25996				
Y Coordinate:	38.71374				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	805	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$100,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5379
Location:	Canyon Oak Dr - North				
X Coordinate:	-121.25764				
Y Coordinate:	38.71489				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	548	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$68,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5380
Location:	Canyon Oak Dr and Garryanna Dr - Corner A				
X Coordinate:	-121.25962				
Y Coordinate:	38.71428				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5381
Location:	Canyon Oak Dr and Garryanna Dr - Corner B				
X Coordinate:	-121.25946				
Y Coordinate:	38.71438				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5382
Location:	Canyon Oak Dr - West				
X Coordinate:	-121.25964				
Y Coordinate:	38.7142				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	509	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$63,625.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5383
Location:	Canyon Oak Dr and Glencreek Wy - Corner A				
X Coordinate:	-121.26037				
Y Coordinate:	38.71293				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5384
Location:	Canyon Oak Dr and Glencreek Wy - Corner D				
X Coordinate:	-121.26036				
Y Coordinate:	38.71284				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5385
Location:	Canyon Oak Dr - West				
X Coordinate:	-121.2603				
Y Coordinate:	38.71274				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1010	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$126,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5386A

Location: Holly Oak St - North

X Coordinate: -121.2583

Y Coordinate: 38.7106

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 200 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$25,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/11/2011 Report Date: 2/14/2011 Barrier #: 5386B

Location: Holly Oak St - North

X Coordinate: -121.25843

Y Coordinate: 38.71052

Barrier Area: Sidewalks

Barrier Type: Surface Condition - Damaged

Code Ref: CBC 1133B.7.1 and ADA/ABA 302.1



As Built Meas: 8 Quantity: LF

Description: Surface is not firm and stable (cracked, broken or loose soil, etc.)

As Built Desc: Cracked concrete

Solution: Repair surface to make firm and stable

Bar. Severity: 1 Necessary Cost Estimate: \$1,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5387A
Location:	Coral Oak Wy - East				
X Coordinate:	-121.25895				
Y Coordinate:	38.7104				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1127	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$140,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/11/2011	Report Date:	2/14/2011	Barrier #:	5387B
Location:	Coral Oak Wy - East				
X Coordinate:	-121.25952				
Y Coordinate:	38.71116				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5388
Location:	Coral Oak Wy and Glen Creek Wy - Corner C				
X Coordinate:	-121.26104				
Y Coordinate:	38.71281				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5389
Location:	Coral Oak Wy and Glen Creek Wy - Corner D				
X Coordinate:	-121.26123				
Y Coordinate:	38.71283				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5390
Location:	Glen Creek Wy - South				
X Coordinate:	-121.26097				
Y Coordinate:	38.71283				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	191	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5391
Location:	Glen Creek Wy - North				
X Coordinate:	-121.26056				
Y Coordinate:	38.71296				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	378	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$47,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5392
Location:	Glen Creek Wy and Garry Oak Dr - Corner A				
X Coordinate:	-121.26208				
Y Coordinate:	38.7129				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5393
Location:	Glen Creek Wy and Garry Oak Dr - Corner B				
X Coordinate:	-121.26183				
Y Coordinate:	38.7129				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5394
Location:	Glen Creek Wy and Garry Oak Dr - Corner C				
X Coordinate:	-121.26183				
Y Coordinate:	38.71277				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5395
Location:	Glen Creek Wy and Garry Oak Dr - Corner D				
X Coordinate:	-121.2621				
Y Coordinate:	38.71275				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5396
Location:	Glen Creek Wy - South				
X Coordinate:	-121.26183				
Y Coordinate:	38.71277				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	173	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,625.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5397
Location:	Coral Oak Wy - West				
X Coordinate:	-121.26121				
Y Coordinate:	38.7128				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	315	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$39,375.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5398
Location:	Coral Oak Wy and Coral Oak Ct - Corner A				
X Coordinate:	-121.26104				
Y Coordinate:	38.71192				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	10.1% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5399
Location:	Coral Oak Wy and Coral Oak Ct - Corner D				
X Coordinate:	-121.26088				
Y Coordinate:	38.71179				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	9.8% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5400

Location: Coral Oak Ct - North

X Coordinate: -121.26109

Y Coordinate: 38.71191

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 95 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$11,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5401

Location: Coral Oak Ct - South

X Coordinate: -121.2611

Y Coordinate: 38.71165

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 95 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$11,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5402
Location:	Coral Oak Wy - West				
X Coordinate:	-121.26077				
Y Coordinate:	38.71173				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	332	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.2% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$41,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5403
Location:	Coral Oak Wy and Coral Oak Ct - Corner A				
X Coordinate:	-121.2598				
Y Coordinate:	38.7112				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	7.3% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5404

Location: Coral Oak Wy and Coral Oak Ct - Corner D

X Coordinate: -121.2597

Y Coordinate: 38.71113

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 9.0% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,D

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5405A

Location: Coral Oak Ct - North

X Coordinate: -121.25989

Y Coordinate: 38.71111

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 106 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$13,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5405B
Location:	Coral Oak Ct - North				
X Coordinate:	-121.25997				
Y Coordinate:	38.71106				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	30" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5406
Location:	Coral Oak Ct - South				
X Coordinate:	-121.26001				
Y Coordinate:	38.71087				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	170	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5407
Location:	Coral Oak Wy - West				
X Coordinate:	-121.25957				
Y Coordinate:	38.71107				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	521	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$65,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5408
Location:	Coral Oak Wy - West				
X Coordinate:	-121.25879				
Y Coordinate:	38.70983				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	45	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5409
Location:	Old Auburn Rd - North				
X Coordinate:	-121.25872				
Y Coordinate:	38.70969				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	900	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$90,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5410
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26156				
Y Coordinate:	38.70855				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	54	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5411
Location:	Old Auburn Blvd and Garry Oak Dr - Corner A				
X Coordinate:	-121.26196				
Y Coordinate:	38.70848				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5412
Location:	Old Auburn Blvd and Garry Oak Dr - Corner B				
X Coordinate:	-121.26182				
Y Coordinate:	38.70857				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5413
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26188				
Y Coordinate:	38.70868				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	173	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5414
Location:	Garry Oak Dr and Forest Oak Wy - Corner B				
X Coordinate:	-121.26189				
Y Coordinate:	38.70917				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	6.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5415
Location:	Garry Oak Dr and Forest Oak Wy - Corner C				
X Coordinate:	-121.26187				
Y Coordinate:	38.70904				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5416A
Location:	Forest Oak Wy - South				
X Coordinate:	-121.26184				
Y Coordinate:	38.70908				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	662	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$82,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5416B
Location:	Forest Oak Wy - South				
X Coordinate:	-121.26178				
Y Coordinate:	38.70906				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - Tree Heaves				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF	
Description:	Change in level greater than 1/2"			
As Built Desc:	1/2" lip due to tree heaves			
Solution:	Grind or repair sidewalk to remove trip hazard			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				
Notes:				

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5417
Location:	Forest Oak Wy - South				
X Coordinate:	-121.25977				
Y Coordinate:	38.70983				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB	
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided			
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder			
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				
Notes:				

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5418
Location:	Forest Oak Wy - North				
X Coordinate:	-121.2598				
Y Coordinate:	38.70991				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5419
Location:	Forest Oak Wy - North				
X Coordinate:	-121.2599				
Y Coordinate:	38.70988				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	314	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$39,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5420
Location:	Forest Oak Wy and Sylvan Oak Wy - Corner A				
X Coordinate:	-121.261				
Y Coordinate:	38.70945				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.7% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5421
Location:	Forest Oak Wy and Sylvan Oak Wy - Corner B				
X Coordinate:	-121.26093				
Y Coordinate:	38.70955				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	12.6% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5422

Location: Sylvan Oak Wy - East

X Coordinate: -121.26093

Y Coordinate: 38.70955

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 364 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$45,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5423

Location: Sylvan Oak Wy and Sylvan Oak Ct - Corner B

X Coordinate: -121.26101

Y Coordinate: 38.71071

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 11.3% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5424
Location:	Sylvan Oak Wy and Sylvan Oak Ct - Corner C				
X Coordinate:	-121.26104				
Y Coordinate:	38.71055				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5425
Location:	Sylvan Oak Ct - South				
X Coordinate:	-121.26097				
Y Coordinate:	38.71055				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	103	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$12,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5426
Location:	Sylvan Oak Ct - North				
X Coordinate:	-121.26077				
Y Coordinate:	38.71075				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	103	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$12,875.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5427A
Location:	Sylvan Oak Wy - East				
X Coordinate:	-121.26106				
Y Coordinate:	38.71078				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	119	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.6% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$14,875.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5427B
Location:	Sylvan Oak Wy - East				
X Coordinate:	-121.26105				
Y Coordinate:	38.71081				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing (32" to 35")				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide (32" to 35")		
As Built Desc:	32" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	2 Recommended	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5428
Location:	Sylvan Oak Wy - North				
X Coordinate:	-121.26116				
Y Coordinate:	38.71112				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	241	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$30,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5429
Location:	Sylvan Oak Wy and Garry Oak Dr - Corner B				
X Coordinate:	-121.26194				
Y Coordinate:	38.71112				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5430
Location:	Sylvan Oak Wy and Garry Oak Dr - Corner C				
X Coordinate:	-121.26188				
Y Coordinate:	38.71096				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	14.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5431
Location:	Sylvan Oak Wy - South				
X Coordinate:	-121.26183				
Y Coordinate:	38.71099				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	189	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,625.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5432
Location:	Sylvan Oak Wy - West				
X Coordinate:	-121.26119				
Y Coordinate:	38.7109				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	548	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.8% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$68,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5433A
Location:	Forest Oak Wy - North				
X Coordinate:	-121.2611				
Y Coordinate:	38.70938				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	273	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$34,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5433B
Location:	Forest Oak Wy - North				
X Coordinate:	-121.26116				
Y Coordinate:	38.70935				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	30" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5434A
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26192				
Y Coordinate:	38.70928				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	652	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.8% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$81,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5434B
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26188				
Y Coordinate:	38.70934				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	16	Quantity:	LF		
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)				
As Built Desc:	Cracked concrete				
Solution:	Repair surface to make firm and stable				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5435
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26196				
Y Coordinate:	38.71119				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	583	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.1% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$72,875.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5436
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26196				
Y Coordinate:	38.71298				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	213	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	6.6% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$26,625.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5437
Location:	Garry Oak Dr and Lobata St - Corner B				
X Coordinate:	-121.26187				
Y Coordinate:	38.71368				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5438
Location:	Garry Oak Dr and Lobata St - Corner C				
X Coordinate:	-121.26186				
Y Coordinate:	38.71354				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5439A
Location:	Lobata St - South				
X Coordinate:	-121.26185				
Y Coordinate:	38.71354				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	242	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$30,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5439B
Location:	Lobata St - South				
X Coordinate:	-121.26101				
Y Coordinate:	38.71356				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	8.0% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5440
Location:	Lobata St - East				
X Coordinate:	-121.26097				
Y Coordinate:	38.71358				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	318	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5441
Location:	Lobata St - South				
X Coordinate:	-121.26056				
Y Coordinate:	38.71437				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	222	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$27,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5442
Location:	Lobata St and Garryanna Dr - Corner A				
X Coordinate:	-121.2601				
Y Coordinate:	38.71488				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5443
Location:	Lobata St and Garryanna Dr - Corner B				
X Coordinate:	-121.25983				
Y Coordinate:	38.71484				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5444
Location:	Lobata St and Garryanna Dr - Corner C				
X Coordinate:	-121.25984				
Y Coordinate:	38.71484				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5445
Location:	Lobata St and Garryanna Dr - Corner D				
X Coordinate:	-121.25998				
Y Coordinate:	38.71476				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5446A
Location:	Lobata St - South				
X Coordinate:	-121.25978				
Y Coordinate:	38.71489				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	618	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.9% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$77,250.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5446B
Location:	Lobata St - South				
X Coordinate:	-121.25974				
Y Coordinate:	38.71492				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5447
Location:	Lobata St - North				
X Coordinate:	-121.25789				
Y Coordinate:	38.71557				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	269	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.8% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$33,625.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5448
Location:	Lobata St and Holm Oak Wy - Corner A				
X Coordinate:	-121.25881				
Y Coordinate:	38.71533				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	7.9% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5449
Location:	Lobata St and Holm Oak Wy - Corner B				
X Coordinate:	-121.25871				
Y Coordinate:	38.71537				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5450
Location:	Lobata St - North				
X Coordinate:	-121.25892				
Y Coordinate:	38.71529				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	314	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5451A
Location:	Lobata St - West				
X Coordinate:	-121.26015				
Y Coordinate:	38.71485				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	231	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.1% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$28,875.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5451B
Location:	Lobata St - West				
X Coordinate:	-121.26034				
Y Coordinate:	38.71467				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5452
Location:	Lobata St and Lobata Ct - Corner A				
X Coordinate:	-121.2607				
Y Coordinate:	38.71437				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5453
Location:	Lobata St and Lobata Ct - Corner D				
X Coordinate:	-121.26076				
Y Coordinate:	38.71427				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	8.9% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5454

Location: Lobata Ct - North

X Coordinate: -121.26079

Y Coordinate: 38.71441

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 176 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.7% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$22,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5455

Location: Lobata Ct - South

X Coordinate: -121.26123

Y Coordinate: 38.71449

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 176 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.1% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$22,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5456A
Location:	Lobata St - West				
X Coordinate:	-121.2608				
Y Coordinate:	38.71423				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	239	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.0% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$29,875.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5456B
Location:	Lobata St - West				
X Coordinate:	-121.26113				
Y Coordinate:	38.71364				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF		
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)				
As Built Desc:	6.6% cross slope				
Solution:	Demolish existing and construct new sidewalk without curb ramp				
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5457
Location:	Lobata St - North				
X Coordinate:	-121.26122				
Y Coordinate:	38.71364				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	225	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5458
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26199				
Y Coordinate:	38.7137				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	620	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$77,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5459
Location:	Garry Oak Dr and Garryanna Dr - Corner A				
X Coordinate:	-121.26204				
Y Coordinate:	38.71552				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	10.4% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Four - way intersection corners A,B,C,D				

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5460
Location:	Garry Oak Dr and Garryanna Dr - Corner B				
X Coordinate:	-121.26183				
Y Coordinate:	38.71553				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.1% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Four - way intersection corners A,B,C,D				

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5461
Location:	Garry Oak Dr and Garryanna Dr - Corner C				
X Coordinate:	-121.26185				
Y Coordinate:	38.71534				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	11.0% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5462
Location:	Garry Oak Dr and Garryanna Dr - Corner D				
X Coordinate:	-121.262				
Y Coordinate:	38.71533				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	9.4% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Four - way intersection corners A,B,C,D

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5463
Location:	Garryanna Dr - South				
X Coordinate:	-121.26179				
Y Coordinate:	38.71537				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	552	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$69,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5464
Location:	Garryanna Dr - West				
X Coordinate:	-121.25994				
Y Coordinate:	38.71473				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	188	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$23,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5465

Location: Garryanna Dr - East

X Coordinate: -121.2595

Y Coordinate: 38.71435

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 188 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.0% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$23,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5466

Location: Garryanna Dr - North

X Coordinate: -121.26

Y Coordinate: 38.71495

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 580 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.9% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$72,500.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5467
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26189				
Y Coordinate:	38.7156				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	237	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$29,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5468
Location:	English Oak Wy - South				
X Coordinate:	-121.26177				
Y Coordinate:	38.71618				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	764	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$95,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5469
Location:	English Oak Wy - North				
X Coordinate:	-121.25933				
Y Coordinate:	38.71603				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	741	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.1% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$92,625.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5470
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26187				
Y Coordinate:	38.71637				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	343	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.2% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$42,875.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5471
Location:	Garry Oak Dr and Holm Oak Wy - Corner B				
X Coordinate:	-121.26187				
Y Coordinate:	38.71744				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	11.2% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5472
Location:	Garry Oak Dr and Holm Oak Wy - Corner C				
X Coordinate:	-121.26186				
Y Coordinate:	38.71729				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.8% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5473
Location:	Holm Oak Wy - South				
X Coordinate:	-121.26177				
Y Coordinate:	38.7173				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	631	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$78,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5474
Location:	Holm Oak Wy - West				
X Coordinate:	-121.25974				
Y Coordinate:	38.71672				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	283	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$35,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5475

Location: Holm Oak Wy - West

X Coordinate: -121.2592

Y Coordinate: 38.7159

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 248 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$31,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5476

Location: Holm Oak Wy - East

X Coordinate: -121.25879

Y Coordinate: 38.71538

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 503 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 4.0% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$62,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5477
Location:	Holm Oak Wy - North				
X Coordinate:	-121.25947				
Y Coordinate:	38.71672				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	775	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$96,875.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5478
Location:	Garry Oak Dr - East				
X Coordinate:	-121.26188				
Y Coordinate:	38.71749				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$12,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5479
Location:	Garry Oak Dr - West				
X Coordinate:	-121.26195				
Y Coordinate:	38.7184				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1084	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$135,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5480
Location:	Garryanna Dr - North				
X Coordinate:	-121.26207				
Y Coordinate:	38.71546				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	229	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$28,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5481
Location:	Garryanna Dr and Peregrine Wy - Corner A				
X Coordinate:	-121.26298				
Y Coordinate:	38.71548				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5482
Location:	Garryanna Dr and Peregrine Wy - Corner B				
X Coordinate:	-121.26286				
Y Coordinate:	38.71546				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5483
Location:	Garryanna Dr - North				
X Coordinate:	-121.26316				
Y Coordinate:	38.71541				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	186	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.4% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$23,250.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5484
Location:	Garryanna Dr and Charlotte Ave - Corner A				
X Coordinate:	-121.26388				
Y Coordinate:	38.71542				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	10.1% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5485
Location:	Garryanna Dr and Charlotte Ave - Corner B				
X Coordinate:	-121.26377				
Y Coordinate:	38.71547				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	11.6% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5486
Location:	Charlotte Ave - East				
X Coordinate:	-121.26374				
Y Coordinate:	38.71667				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	386	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$48,250.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5487
Location:	Charlotte Ave and Peregrine Wy - Corner B				
X Coordinate:	-121.26372				
Y Coordinate:	38.71653				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.4% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5488
Location:	Charlotte Ave and Peregrine Wy - Corner C				
X Coordinate:	-121.26367				
Y Coordinate:	38.71654				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5489A
Location:	Peregrine Wy - South				
X Coordinate:	-121.26304				
Y Coordinate:	38.71652				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	185	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$23,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5489B
Location:	Peregrine Wy - South				
X Coordinate:	-121.26303				
Y Coordinate:	38.71645				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	6	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (5.0% or more)		
As Built Desc:	12.2% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5490
Location:	Peregrine Wy - West				
X Coordinate:	-121.2629				
Y Coordinate:	38.71566				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	370	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$46,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5491
Location:	Peregrine Wy - East				
X Coordinate:	-121.26308				
Y Coordinate:	38.71665				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	383	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.7% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5492

Location: Peregrine Wy - North

X Coordinate: -121.26403

Y Coordinate: 38.71684

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 191 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.4% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$23,875.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5493

Location: Keesee Wy - North

X Coordinate: -121.26479

Y Coordinate: 38.71687

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (4.1% to 4.9%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 61 Quantity: LF

Description: Cross slope exceeds 2.0% (4.1% to 4.9%)

As Built Desc: 4.3% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 2 Recommended Cost Estimate: \$7,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5494
Location:	Keesee Wy - North				
X Coordinate:	-121.26479				
Y Coordinate:	38.71684				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Cane Detectable Barricade				
Code Ref:	CBC 1133B.8.6 and MUTCD Section 6D.02				



As Built Meas:	60	Quantity:	LF
Description:	No cane detectable warning on existing barricade		
As Built Desc:	Existing barricade lacks warning for the visually impaired		
Solution:	Provide cane detectable warning on barricade (max. 6" above ground)		
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5495A
Location:	Keesee Wy - South				
X Coordinate:	-121.26422				
Y Coordinate:	38.71673				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	88	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$11,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5495B

Location: Keesee Wy - South

X Coordinate: -121.26388

Y Coordinate: 38.71675

Barrier Area: Sidewalks

Barrier Type: Elbow in Sidewalk - Cross Slope (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 6 Quantity: LF

Description: Cross slope at elbow exceeds 2.0% (5.0% or more)

As Built Desc: 10.7% cross slope

Solution: Demolish existing and construct new sidewalk without curb ramp

Bar. Severity: 1 Necessary

Cost Estimate: \$750.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date: 2/15/2011 Report Date: 2/28/2011 Barrier #: 5496

Location: Charlotte Ave - West

X Coordinate: -121.26389

Y Coordinate: 38.7167

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 470 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 3.2% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance

Cost Estimate: \$58,750.00

Status:

Implementation Priority: 4

Facility Function:

Implementation Phase:

Implementation Date:

Official Responsible:

Notes:

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5497
Location:	Garryanna Dr - North				
X Coordinate:	-121.26392				
Y Coordinate:	38.7154				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	94	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$11,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5498
Location:	Garryanna Dr - North				
X Coordinate:	-121.2642				
Y Coordinate:	38.71536				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Cane Detectable Barricade				
Code Ref:	CBC 1133B.8.6 and MUTCD Section 6D.02				



As Built Meas:	60	Quantity:	LF
Description:	No cane detectable warning on existing barricade		
As Built Desc:	Existing barricade lacks warning for the visually impaired		
Solution:	Provide cane detectable warning on barricade (max. 6" above ground)		
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5499A
Location:	Garryanna Dr - South				
X Coordinate:	-121.26416				
Y Coordinate:	38.71528				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	625	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.6% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$78,125.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5499B
Location:	Garryanna Dr - South				
X Coordinate:	-121.26336				
Y Coordinate:	38.71527				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	6	Quantity:	LF		
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)				
As Built Desc:	Cracked concrete				
Solution:	Repair surface to make firm and stable				
Bar. Severity:	1 Necessary	Cost Estimate:	\$750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5500A
Location:	Garry Oak Dr - West				
X Coordinate:	-121.26202				
Y Coordinate:	38.71529				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	890	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$111,250.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/15/2011	Report Date:	2/28/2011	Barrier #:	5500B
Location:	Garry Oak Dr - West				
X Coordinate:	-121.26208				
Y Coordinate:	38.71392				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF		
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)				
As Built Desc:	24" clear width due to foliage				
Solution:	Trim foliage to provide min. 48" clear width				
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5501
Location:	Gary Oak Dr - West				
X Coordinate:	-121.26208				
Y Coordinate:	38.71269				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	721	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$90,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5502
Location:	Gary Oak Dr - West				
X Coordinate:	-121.2621				
Y Coordinate:	38.7113				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	4	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5503
Location:	Gary Oak Dr and Forrest Glen Wy - Corner A				
X Coordinate:	-121.26211				
Y Coordinate:	38.71074				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5504A
Location:	Gary Oak Dr and Forrest Glen Wy - Corner D				
X Coordinate:	-121.26209				
Y Coordinate:	38.7106				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5504B
Location:	Gary Oak Dr and Forrest Glen Wy - Corner D				
X Coordinate:	-121.26209				
Y Coordinate:	38.7106				
Barrier Area:	Curb Ramps				
Barrier Type:	Lip - Gutter to Asphalt Transition				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 303.3				



As Built Meas:	1	Quantity:	EACH
Description:	Transition at transition into asphalt not flush and free of any lip		
As Built Desc:	1/2" lip at asphalt transition into roadway		
Solution:	Remove lip to create flush transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5505
Location:	Gary Oak Dr - West				
X Coordinate:	-121.26207				
Y Coordinate:	38.71053				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	756	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$94,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5506
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.262				
Y Coordinate:	38.70844				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	305	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$38,125.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5507
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26208				
Y Coordinate:	38.70841				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5508
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26373				
Y Coordinate:	38.70767				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	2	Quantity:	LF		
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)				
As Built Desc:	24" clear width due to pole				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$250.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5509A
Location:	Old Auburn Blvd and Glen Echo St - Corner A				
X Coordinate:	-121.26428				
Y Coordinate:	38.70748				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	2	Quantity:	EACH		
Description:	12" grooves at top of curb ramp are not level (3.1% to 4.0%)				
As Built Desc:	3.3% at 12" grooves				
Solution:	Demolish existing and construct new curb ramp				
Bar. Severity:	3 Hindrance	Cost Estimate:	\$5,000.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Two - way intersection corners A,B				

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5509B
Location:	Old Auburn Blvd and Glen Echo St - Corner A				
X Coordinate:	-121.26428				
Y Coordinate:	38.70748				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH		
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)				
As Built Desc:	10.8% running slope				
Solution:	Demolish existing and construct new curb ramp				
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5509C
Location:	Old Auburn Blvd and Glen Echo St - Corner A				
X Coordinate:	-121.26428				
Y Coordinate:	38.70748				
Barrier Area:	Curb Ramps				
Barrier Type:	Perpendicular Ramp Landing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH		
Description:	Curb ramp top landing not level (3.1% to 4.0%)				
As Built Desc:	3.1% landing slope				
Solution:	Demolish existing and construct new transition				
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date: 2/28/2011 Report Date: 3/1/2011 Barrier #: 5509D

Location: Old Auburn Blvd and Glen Echo St - Corner A

X Coordinate: -121.26428

Y Coordinate: 38.70748

Barrier Area: Curb Ramps

Barrier Type: Detectable Warnings - Truncated Domes

Code Ref: CBC 1127B.5.7 and ADA/ABA 705.1.3



As Built Meas: 1 Quantity: EACH

Description: No truncated domes provided at curb ramp

As Built Desc: No detectable warnings at curb ramp

Solution: Provide compliant truncated domes

Bar. Severity: 2 Recommended Cost Estimate: \$0.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date: 2/28/2011 Report Date: 3/1/2011 Barrier #: 5509E

Location: Old Auburn Blvd and Glen Echo St - Corner A

X Coordinate: -121.26428

Y Coordinate: 38.70748

Barrier Area: Curb Ramps

Barrier Type: Gutter Slope - Existing (8.3% or more)

Code Ref: CBC 1127B.5.3 and ADA/ABA 406.2



As Built Meas: 6 Quantity: SF

Description: Gutter slope exceeds 5.0% (8.3% or more)

As Built Desc: 10.6% gutter slope

Solution: Demolish existing and construct new gutter

Bar. Severity: 1 Necessary Cost Estimate: \$0.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5510A
Location:	Old Auburn Blvd and Glen Echo St - Corner B				
X Coordinate:	-121.26411				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	9.5% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5510B
Location:	Old Auburn Blvd and Glen Echo St - Corner B				
X Coordinate:	-121.26411				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5510C
Location:	Old Auburn Blvd and Glen Echo St - Corner B				
X Coordinate:	-121.26411				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	Perpendicular Ramp Landing (3.1% to 4.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH		
Description:	Curb ramp top landing not level (3.1% to 4.0%)				
As Built Desc:	3.5% landing slope				
Solution:	Demolish existing and construct new transition				
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5510D
Location:	Old Auburn Blvd and Glen Echo St - Corner B				
X Coordinate:	-121.26411				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at curb ramp				
As Built Desc:	No detectable warnings at curb ramp				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5510E
Location:	Old Auburn Blvd and Glen Echo St - Corner B				
X Coordinate:	-121.26411				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (8.3% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF
Description:	Gutter slope exceeds 5.0% (8.3% or more)		
As Built Desc:	17.0% gutter slope		
Solution:	Demolish existing and construct new gutter		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5511
Location:	Glen Echo St - East				
X Coordinate:	-121.26418				
Y Coordinate:	38.70992				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5512
Location:	Glen Echo St - West				
X Coordinate:	-121.26439				
Y Coordinate:	38.71011				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	89	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$11,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5513
Location:	Glen Echo St and Glen Briar Dr - Corner A				
X Coordinate:	-121.26436				
Y Coordinate:	38.70937				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5514
Location:	Glen Echo St and Glen Briar Dr - Corner D				
X Coordinate:	-121.26438				
Y Coordinate:	38.70925				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No curb cut at corner (intersection)				
As Built Desc:	No curb ramp at corner				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,D				
--------	------------------------------------	--	--	--	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5515
Location:	Glen Echo St - West				
X Coordinate:	-121.26435				
Y Coordinate:	38.70837				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5516A
Location:	Glen Echo St - West				
X Coordinate:	-121.26434				
Y Coordinate:	38.70831				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	325	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5516B
Location:	Glen Echo St - West				
X Coordinate:	-121.26434				
Y Coordinate:	38.70811				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5517
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.2648				
Y Coordinate:	38.70723				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF		
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	9.7% cross slope				
Solution:	Provide min. 48" wide level walkway through driveway				
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,000.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5518
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26493				
Y Coordinate:	38.70715				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$12,500.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5519
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26527				
Y Coordinate:	38.70703				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	45	Quantity:	LF	
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	9.7% cross slope			
Solution:	Provide min. 48" wide level walkway through driveway			
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,625.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5520A
Location:	Old Auburn Blvd and Dannon Ct - Corner A				
X Coordinate:	-121.2656				
Y Coordinate:	38.70689				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH	
Description:	12" grooves at top of curb ramp are not level (2.1% to 3.0%)			
As Built Desc:	2.9% at 12" grooves			
Solution:	Demolish existing and construct new curb ramp			
Bar. Severity:	4 Low Severity	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5520B
Location:	Old Auburn Blvd and Dannon Ct - Corner A				
X Coordinate:	-121.2656				
Y Coordinate:	38.70689				
Barrier Area:	Curb Ramps				
Barrier Type:	Perpendicular Ramp Landing (2.1% to 3.0%)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH	
Description:	Curb ramp top landing not level (2.1% to 3.0%)			
As Built Desc:	2.5% landing slope			
Solution:	Demolish existing and construct new transition			
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5520C
Location:	Old Auburn Blvd and Dannon Ct - Corner A				
X Coordinate:	-121.2656				
Y Coordinate:	38.70689				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH	
Description:	No truncated domes provided at curb ramp			
As Built Desc:	No detectable warnings at curb ramp			
Solution:	Provide compliant truncated domes			
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5520D
Location:	Old Auburn Blvd and Dannon Ct - Corner A				
X Coordinate:	-121.2656				
Y Coordinate:	38.70689				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF		
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)				
As Built Desc:	6.6% gutter slope				
Solution:	Demolish existing and construct new gutter				
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5521
Location:	Old Auburn Blvd and Dannon Ct - Corner B				
X Coordinate:	-121.26544				
Y Coordinate:	38.70695				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at curb ramp				
As Built Desc:	No detectable warnings at curb ramp				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5522
Location:	Dannon Ct - East				
X Coordinate:	-121.26548				
Y Coordinate:	38.70702				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5523
Location:	Dannon Ct - East				
X Coordinate:	-121.26549				
Y Coordinate:	38.70779				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5524A
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26573				
Y Coordinate:	38.70682				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	189	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$23,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5524B
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.26591				
Y Coordinate:	38.70673				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5524C
Location:	Old Auburn Blvd - North				
X Coordinate:	-121.2662				
Y Coordinate:	38.70661				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5525
Location:	Old Auburn Blvd and Glen Tree Dr - Corner A				
X Coordinate:	-121.26648				
Y Coordinate:	38.70653				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5526A
Location:	Old Auburn Blvd and Glen Tree Dr - Corner B				
X Coordinate:	-121.26629				
Y Coordinate:	38.70658				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH
Description:	12" grooves at top of curb ramp are not level (4.1% to 4.9%)		
As Built Desc:	4.8% at 12" grooves		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5526B
Location:	Old Auburn Blvd and Glen Tree Dr - Corner B				
X Coordinate:	-121.26629				
Y Coordinate:	38.70658				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)		
As Built Desc:	12.3% running slope		
Solution:	Demolish existing and construct new curb ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5526C
Location:	Old Auburn Blvd and Glen Tree Dr - Corner B				
X Coordinate:	-121.26629				
Y Coordinate:	38.70658				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5526D
Location:	Old Auburn Blvd and Glen Tree Dr - Corner B				
X Coordinate:	-121.26629				
Y Coordinate:	38.70658				
Barrier Area:	Curb Ramps				
Barrier Type:	Perpendicular Ramp Landing (>5.0% or more)				
Code Ref:	CBC 1127B.5.4 and ADA/ABA 406.4				



As Built Meas:	1	Quantity:	EACH
Description:	Curb ramp top landing not level (>5.0% or more)		
As Built Desc:	5.8% landing slope		
Solution:	Demolish existing and construct new transition		
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,B

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5527
Location:	Glen Tree Dr - East				
X Coordinate:	-121.26638				
Y Coordinate:	38.7067				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	637	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.5% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$79,625.00	Status:
Implementation Priority:	3	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5528
Location:	Glen Eva - South				
X Coordinate:	-121.2664				
Y Coordinate:	38.70848				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	580	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.8% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$72,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5529
Location:	Glen Eva - North				
X Coordinate:	-121.26455				
Y Coordinate:	38.70859				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	579	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$72,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5530
Location:	Glen Eva - East				
X Coordinate:	-121.26654				
Y Coordinate:	38.7086				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	701	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$87,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5531
Location:	Glen Tree Dr and Glen Briar Dr - Corner B				
X Coordinate:	-121.26647				
Y Coordinate:	38.70929				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5532
Location:	Glen Tree Dr and Glen Briar Dr - Corner C				
X Coordinate:	-121.2665				
Y Coordinate:	38.7092				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5533
Location:	Glen Briar Dr - South				
X Coordinate:	-121.26641				
Y Coordinate:	38.70917				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	572	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$71,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5534
Location:	Glen Briar Dr and Glen Field Ct - Corner A				
X Coordinate:	-121.26533				
Y Coordinate:	38.70934				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5535
Location:	Glen Briar Dr and Glen Field Ct - Corner B				
X Coordinate:	-121.2652				
Y Coordinate:	38.70933				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5536
Location:	Glen Field Ct - East				
X Coordinate:	-121.2652				
Y Coordinate:	38.70937				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	402	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$50,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5537
Location:	Glen Field Ct - West				
X Coordinate:	-121.26545				
Y Coordinate:	38.70926				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	424	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$53,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5538
Location:	Glen Briar Dr - North				
X Coordinate:	-121.26651				
Y Coordinate:	38.70936				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	308	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$38,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5539
Location:	Glen Tree Dr - East				
X Coordinate:	-121.26656				
Y Coordinate:	38.71096				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	552	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$69,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5540
Location:	Glen Tree Dr and Glen Park Ave - Corner B				
X Coordinate:	-121.26654				
Y Coordinate:	38.71088				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5541
Location:	Glen Tree Dr and Glen Park Ave - Corner C				
X Coordinate:	-121.26645				
Y Coordinate:	38.7109				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5542
Location:	Glen Park Ave - South				
X Coordinate:	-121.26466				
Y Coordinate:	38.71102				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	581	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$72,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5543A
Location:	Glen Park Ave - North				
X Coordinate:	-121.26464				
Y Coordinate:	38.71101				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	554	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.4% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$69,250.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5543B
Location:	Glen Park Ave - North				
X Coordinate:	-121.26564				
Y Coordinate:	38.71104				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5544A
Location:	Glen Tree Dr - East				
X Coordinate:	-121.26656				
Y Coordinate:	38.71111				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	192	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$24,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5544B
Location:	Glen Tree Dr - East				
X Coordinate:	-121.26655				
Y Coordinate:	38.71144				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5545
Location:	Glen Valley Cir - South				
X Coordinate:	-121.26642				
Y Coordinate:	38.71171				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	314	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5546
Location:	Glen Valley Cir - East				
X Coordinate:	-121.26534				
Y Coordinate:	38.71182				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	414	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$51,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5547
Location:	Glen Valley Cir - North				
X Coordinate:	-121.26568				
Y Coordinate:	38.71286				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	251	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$31,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5548
Location:	Glen Valley Cir - South				
X Coordinate:	-121.26608				
Y Coordinate:	38.71289				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	71	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$8,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5549
Location:	Glen Valley Cir - West				
X Coordinate:	-121.26583				
Y Coordinate:	38.71277				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	348	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5550
Location:	Glen Valley Cir - North				
X Coordinate:	-121.26557				
Y Coordinate:	38.71185				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	454	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$56,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5551
Location:	Glen Valley Cir - East				
X Coordinate:	-121.26648				
Y Coordinate:	38.71186				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	357	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$44,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5552
Location:	Glen Valley Cir - East				
X Coordinate:	-121.26658				
Y Coordinate:	38.71311				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	582	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$72,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5553
Location:	Glen Tree Dr and Glen Creek Wy - Corner C				
X Coordinate:	-121.26565				
Y Coordinate:	38.71465				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5554
Location:	Glen Tree Dr and Glen Creek Wy - Corner D				
X Coordinate:	-121.26577				
Y Coordinate:	38.71453				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5555
Location:	Glen Creek Wy - West				
X Coordinate:	-121.26573				
Y Coordinate:	38.71451				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	366	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5556
Location:	Glen Creek Wy - South				
X Coordinate:	-121.26393				
Y Coordinate:	38.71284				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	723	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.8% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	2 Recommended	Cost Estimate:	\$90,375.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5557
Location:	Glen Creek Wy and Glen Alta Wy - Corner A				
X Coordinate:	-121.26533				
Y Coordinate:	38.71357				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	14.0% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Four - way intersection corners A,B,C,D				

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5558
Location:	Glen Creek Wy and Glen Alta Wy - Corner B				
X Coordinate:	-121.26306				
Y Coordinate:	38.71289				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	13.8% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:	Four - way intersection corners A,B,C,D				

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5559
Location:	Glen Creek Wy and Glen Alta Wy - Corner C				
X Coordinate:	-121.2629				
Y Coordinate:	38.71289				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	14.7% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5560
Location:	Glen Creek Wy and Glen Alta Wy - Corner D				
X Coordinate:	-121.26289				
Y Coordinate:	38.71275				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	13.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5561
Location:	Glen Alta Wy - West				
X Coordinate:	-121.26305				
Y Coordinate:	38.71273				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	194	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5562
Location:	Glen Alta Wy - North				
X Coordinate:	-121.2631				
Y Coordinate:	38.71213				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	258	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$32,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5563
Location:	Glen Alta Wy - West				
X Coordinate:	-121.26389				
Y Coordinate:	38.71128				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	254	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$31,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5564
Location:	Forrest Glen Wy - South				
X Coordinate:	-121.26356				
Y Coordinate:	38.71061				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	65	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$8,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5565
Location:	Forrest Glen Wy and Tanana River Ct - Corner C				
X Coordinate:	-121.26304				
Y Coordinate:	38.7106				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5566
Location:	Forrest Glen Wy and Tanana River Ct - Corner D				
X Coordinate:	-121.26322				
Y Coordinate:	38.71061				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5567A
Location:	Tanana River Ct - West				
X Coordinate:	-121.26313				
Y Coordinate:	38.71023				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	230	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$28,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5567B
Location:	Tanana River Ct - West				
X Coordinate:	-121.2632				
Y Coordinate:	38.7096				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	26	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	71% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$3,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 2/28/2011 Report Date: 3/1/2011 Barrier #: 5568

Location: Tanana River Ct - East

X Coordinate: -121.26307

Y Coordinate: 38.70956

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 26 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 7.3% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$3,250.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 2/28/2011 Report Date: 3/1/2011 Barrier #: 5569

Location: Tanana River Ct - East

X Coordinate: -121.26297

Y Coordinate: 38.70965

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (3.1% to 4.0%)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 341 Quantity: LF

Description: Cross slope exceeds 2.0% (3.1% to 4.0%)

As Built Desc: 4.0% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 3 Hinderance Cost Estimate: \$42,625.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5570
Location:	Forrest Glen Wy - North				
X Coordinate:	-121.26219				
Y Coordinate:	38.71068				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	295	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	6.0% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$36,875.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5571
Location:	Glen Alta Wy - East				
X Coordinate:	-121.26372				
Y Coordinate:	38.71089				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	134	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	5.4% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$16,750.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5572
Location:	Glen Alta Wy and Debbie Ann Ct - Corner B				
X Coordinate:	-121.26377				
Y Coordinate:	38.71139				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5573
Location:	Glen Alta Wy and Debbie Ann Ct - Corner C				
X Coordinate:	-121.26374				
Y Coordinate:	38.71129				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.6% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners B,C		

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5574
Location:	Debbie Ann Ct - South				
X Coordinate:	-121.26365				
Y Coordinate:	38.7113				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	259	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$32,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5575
Location:	Glen Alta Wy - East				
X Coordinate:	-121.26376				
Y Coordinate:	38.71148				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	200	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$25,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5576A
Location:	Glen Alta Wy - South				
X Coordinate:	-121.26374				
Y Coordinate:	38.71198				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	273	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$34,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5576
Location:	Glen Alta Wy - South				
X Coordinate:	-121.26367				
Y Coordinate:	38.712				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5577
Location:	Glen Alta Wy - East				
X Coordinate:	-121.26284				
Y Coordinate:	38.71219				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	199	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	2/28/2011	Report Date:	3/1/2011	Barrier #:	5578
Location:	Glen Creek Wy - South				
X Coordinate:	-121.26282				
Y Coordinate:	38.71277				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	192	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$24,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5579
Location:	Glen Creek Wy - North				
X Coordinate:	-121.2622				
Y Coordinate:	38.7129				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	206	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.1% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$25,750.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5580
Location:	Glen Creek Wy - North				
X Coordinate:	-121.2631				
Y Coordinate:	38.71291				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	256	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	6.2% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$32,000.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5581
Location:	Glen Creek Wy and Heatherbrook Ct - Corner A				
X Coordinate:	-121.26411				
Y Coordinate:	38.71311				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.3% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5582
Location:	Glen Creek Wy and Heatherbrook Ct - Corner B				
X Coordinate:	-121.26398				
Y Coordinate:	38.71299				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	11.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5583
Location:	Heatherbrook Ct - East				
X Coordinate:	-121.26387				
Y Coordinate:	38.71312				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	172	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$21,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5584
Location:	Heatherbrook Ct - West				
X Coordinate:	-121.26384				
Y Coordinate:	38.71351				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	24	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	Crackd concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$3,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5585
Location:	Glen Brook Wy - East				
X Coordinate:	-121.26423				
Y Coordinate:	38.71321				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	583	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$72,875.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5586
Location:	Glen Brook Wy and Glen Alta Wy - Corner B				
X Coordinate:	-121.26545				
Y Coordinate:	38.71442				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5587
Location:	Glen Brook Wy and Glen Alta Wy - Corner C				
X Coordinate:	-121.26542				
Y Coordinate:	38.7143				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners B,C

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5588
Location:	Glen Alta Wy - South				
X Coordinate:	-121.26513				
Y Coordinate:	38.71432				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	278	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$34,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5589
Location:	Glen Alta Wy and Glen Alta Wy Ct - Corner C				
X Coordinate:	-121.26416				
Y Coordinate:	38.71434				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	12.2% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5590
Location:	Glen Alta Wy and Glen Alta Wy Ct - Corner D				
X Coordinate:	-121.26435				
Y Coordinate:	38.71434				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	14.5% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5591
Location:	Glen Alta Wy Ct - West				
X Coordinate:	-121.26437				
Y Coordinate:	38.71427				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	125	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	5.4% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$15,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5592
Location:	Glen Alta Wy Ct - East				
X Coordinate:	-121.26418				
Y Coordinate:	38.71406				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	108	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$13,500.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5593
Location:	Glen Alta Wy - South				
X Coordinate:	-121.26401				
Y Coordinate:	38.71434				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	317	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5594
Location:	Glen Alta Wy - West				
X Coordinate:	-121.26306				
Y Coordinate:	38.71384				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	325	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$40,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5595
Location:	Glen Alta Wy - East				
X Coordinate:	-121.26281				
Y Coordinate:	38.7131				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	466	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$58,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5596
Location:	Glen Alta Wy - North				
X Coordinate:	-121.26311				
Y Coordinate:	38.71429				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	317	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5597
Location:	Glen Creek Wy - East				
X Coordinate:	-121.26551				
Y Coordinate:	38.71447				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	93	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$11,625.00
Status:			
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5598
Location:	Glen Tree Wy - East				
X Coordinate:	-121.2656				
Y Coordinate:	38.71473				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	209	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$26,125.00
Status:			
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5599
Location:	Glen Tree Wy and Garryanna Dr - Corner C				
X Coordinate:	-121.26544				
Y Coordinate:	38.71529				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	7.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5600
Location:	Glen Tree Wy and Garryanna Dr - Corner D				
X Coordinate:	-121.26573				
Y Coordinate:	38.71528				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.0% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5601
Location:	Garryanna Dr - South				
X Coordinate:	-121.26477				
Y Coordinate:	38.71531				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB		
Description:	No barricade provided where sidewalk ends in hazardous location				
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk				
Solution:	Provide barricade with cane detectable warning at end of sidewalk				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5602
Location:	Garryanna Dr - North				
X Coordinate:	-121.26478				
Y Coordinate:	38.71543				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB		
Description:	No barricade provided where sidewalk ends in hazardous location				
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk				
Solution:	Provide barricade with cane detectable warning at end of sidewalk				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5603A
Location:	Garryanna Dr - North				
X Coordinate:	-121.26536				
Y Coordinate:	38.71543				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	363	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$45,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5603B
Location:	Garryanna Dr - North				
X Coordinate:	-121.26635				
Y Coordinate:	38.71543				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5604
Location:	Garryanna Dr and Manger Wy - Corner A				
X Coordinate:	-121.26679				
Y Coordinate:	38.71542				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	9.5% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5605
Location:	Garryanna Dr and Manger Wy - Corner B				
X Coordinate:	-121.26504				
Y Coordinate:	38.71611				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH		
Description:	No compliant curb cut at corner (intersection)				
As Built Desc:	8.3% running slope at depressed area				
Solution:	Demolish existing and construct curb cut				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5606
Location:	Forgetmenot Ct - North				
X Coordinate:	-121.26608				
Y Coordinate:	38.7161				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - New Construction				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5607
Location:	Manger Wy and Forgetmenot Ct - Corner A				
X Coordinate:	-121.26584				
Y Coordinate:	38.71612				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	9.1% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5608
Location:	Manger Wy and Forgetmenot Ct - Corner B				
X Coordinate:	-121.26591				
Y Coordinate:	38.71634				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH	
Description:	No compliant curb cut at corner (intersection)			
As Built Desc:	10.5% running slope at depressed area			
Solution:	Demolish existing and construct curb cut			
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,B
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5609
Location:	Manger Wy - East				
X Coordinate:	-121.266				
Y Coordinate:	38.71642				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB	
Description:	No barricade provided where sidewalk ends in hazardous location			
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk			
Solution:	Provide barricade with cane detectable warning at end of sidewalk			
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5610
Location:	Manger Wy - West				
X Coordinate:	-121.26606				
Y Coordinate:	38.71635				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	115	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$14,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5611
Location:	Garryanna Dr - North				
X Coordinate:	-121.26699				
Y Coordinate:	38.71536				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	78	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$9,750.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5612
Location:	Garryanna Dr - North				
X Coordinate:	-121.2672				
Y Coordinate:	38.71536				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5613
Location:	Garryanna Dr - South				
X Coordinate:	-121.26721				
Y Coordinate:	38.71527				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5614
Location:	Garryanna Dr - South				
X Coordinate:	-121.26486				
Y Coordinate:	38.71531				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB		
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided				
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder				
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5615
Location:	Garryanna Dr - North				
X Coordinate:	-121.26486				
Y Coordinate:	38.71542				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB		
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided				
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder				
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5616A
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26571				
Y Coordinate:	38.71518				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	365	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.3% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$45,625.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5616
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26577				
Y Coordinate:	38.71491				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5617
Location:	Glen Tree Dr and Glen Arbor Wy - Corner A				
X Coordinate:	-121.26645				
Y Coordinate:	38.71438				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5618
Location:	Glen Tree Dr and Glen Arbor Wy - Corner D				
X Coordinate:	-121.26659				
Y Coordinate:	38.7143				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5619
Location:	Glen Arbor Wy - North				
X Coordinate:	-121.26648				
Y Coordinate:	38.71444				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	219	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0 % cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$27,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5620
Location:	Glen Arbor Wy - North				
X Coordinate:	-121.26713				
Y Coordinate:	38.71462				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to gate		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5620
Location:	Glen Arbor Wy - South				
X Coordinate:	-121.26715				
Y Coordinate:	38.71451				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to gate		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5621
Location:	Glen Arbor Wy - South				
X Coordinate:	-121.26706				
Y Coordinate:	38.71452				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	177	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$22,125.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5622
Location:	Glen Tree Dr - West				
X Coordinate:	-121.2666				
Y Coordinate:	38.71418				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1055	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$131,875.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5623
Location:	Glen Tree Dr and Glen Stone Ave - Corner A				
X Coordinate:	-121.26669				
Y Coordinate:	38.71146				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5624
Location:	Glen Tree Dr and Glen Stone Ave - Corner D				
X Coordinate:	-121.26672				
Y Coordinate:	38.71137				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No curb cut at corner (intersection)		
As Built Desc:	No curb ramp at corner		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5625
Location:	Glen Stone Ave - North				
X Coordinate:	-121.26687				
Y Coordinate:	38.71147				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	363	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$45,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5626
Location:	Glen Stone Ave - North				
X Coordinate:	-121.26803				
Y Coordinate:	38.7113				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	271	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.1% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$33,875.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5627
Location:	Glen Stone Ave - East				
X Coordinate:	-121.26784				
Y Coordinate:	38.71083				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	198	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)			
As Built Desc:	4.5% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	2 Recommended	Cost Estimate:	\$24,750.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5628
Location:	Glen Stone Ave - South				
X Coordinate:	-121.2677				
Y Coordinate:	38.71134				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	292	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.9% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$36,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5629A
Location:	Glen Tree Dr - West				
X Coordinate:	-121.2667				
Y Coordinate:	38.71129				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	490	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$61,250.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5629B
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26672				
Y Coordinate:	38.71116				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - New Construction				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	1	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide		
As Built Desc:	24" clear width due to foliage		
Solution:	Trim foliage to provide min. 48" clear width		
Bar. Severity:	1 Necessary	Cost Estimate:	\$125.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5629C
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26672				
Y Coordinate:	38.7107				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00
Implementation Priority:	3	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5630A
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26664				
Y Coordinate:	38.70975				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	1173	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.0% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$146,625.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5630B
Location:	Glen Tree Dr - West				
X Coordinate:	-121.26674				
Y Coordinate:	38.70776				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	4	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,000.00	Status:	
Implementation Priority:	3	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5631A
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26659				
Y Coordinate:	38.70648				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	259	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$32,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5631
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26731				
Y Coordinate:	38.70622				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	12	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole and guide wire		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5632
Location:	Antelope Rd - East				
X Coordinate:	-121.26753				
Y Coordinate:	38.70619				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5633
Location:	Antelope Rd - East				
X Coordinate:	-121.26827				
Y Coordinate:	38.70721				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5634
Location:	Antelope Rd - East				
X Coordinate:	-121.26826				
Y Coordinate:	38.70723				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB		
Description:	No barricade provided where sidewalk ends in hazardous location				
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk				
Solution:	Provide barricade with cane detectable warning at end of sidewalk				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5635
Location:	Antelope Rd - North				
X Coordinate:	-121.26841				
Y Coordinate:	38.70733				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	319	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.8% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$39,875.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5636
Location:	Antelope Rd and Wonder St - Corner A				
X Coordinate:	-121.26952				
Y Coordinate:	38.70772				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5637A
Location:	Antelope Rd and Wonder St - Corner B				
X Coordinate:	-121.26936				
Y Coordinate:	38.7077				
Barrier Area:	Curb Ramps				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.7 and ADA/ABA 705.1.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at curb ramp		
As Built Desc:	No detectable warnings at curb ramp		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two - way intersection corners A,B		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5637B
Location:	Antelope Rd and Wonder St - Corner B				
X Coordinate:	-121.26936				
Y Coordinate:	38.7077				
Barrier Area:	Curb Ramps				
Barrier Type:	Gutter Slope - Existing (6.6% to 8.2%)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.2				



As Built Meas:	6	Quantity:	SF	
Description:	Gutter slope exceeds 5.0% (6.6% to 8.2%)			
As Built Desc:	7.0% gutter slope			
Solution:	Demolish existing and construct new gutter			
Bar. Severity:	2 Recommended	Cost Estimate:	\$750.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes: Two - way intersection corners A,B

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5638
Location:	Wonder St -East				
X Coordinate:	-121.26937				
Y Coordinate:	38.70803				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	60	Quantity:	LF	
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)			
As Built Desc:	3.8% cross slope			
Solution:	Demolish existing and construct new route			
Bar. Severity:	3 Hinderance	Cost Estimate:	\$7,500.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5639
Location:	Wonder St -East				
X Coordinate:	-121.26936				
Y Coordinate:	38.70837				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	45	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$5,625.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5640
Location:	Wonder St -East				
X Coordinate:	-121.26936				
Y Coordinate:	38.70868				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5641
Location:	Wonder St -East				
X Coordinate:	-121.26938				
Y Coordinate:	38.7088				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	170	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	9.0% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,250.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5642
Location:	Wonder St -East				
X Coordinate:	-121.26937				
Y Coordinate:	38.70925				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	200	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5643
Location:	Wonder St -East and Hanson Ave - Corner A				
X Coordinate:	-121.26955				
Y Coordinate:	38.70991				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5644
Location:	Wonder St -East and Hanson Ave - Corner B				
X Coordinate:	-121.26939				
Y Coordinate:	38.70992				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5645
Location:	Wonder St -East and Hanson Ave - Corner C				
X Coordinate:	-121.26937				
Y Coordinate:	38.70979				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5646
Location:	Wonder St -East and Hanson Ave - Corner D				
X Coordinate:	-121.26952				
Y Coordinate:	38.70978				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Four - way intersection corners A,B,C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5647
Location:	Hanson Ave - South				
X Coordinate:	-121.26898				
Y Coordinate:	38.70978				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	348	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$34,800.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5648A
Location:	Hanson Ave and Charlene Wy - Corner C				
X Coordinate:	-121.26789				
Y Coordinate:	38.70982				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two -way intersection corners C,D
--------	-----------------------------------

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5648B
Location:	Hanson Ave and Charlene Wy - Corner D				
X Coordinate:	-121.26803				
Y Coordinate:	38.70983				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning at transition into roadway		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5649
Location:	Charlene Wy - West				
X Coordinate:	-121.26804				
Y Coordinate:	38.70966				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	439	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$43,900.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5650
Location:	Charlene Wy - West				
X Coordinate:	-121.26806				
Y Coordinate:	38.70862				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5651
Location:	Charlene Wy - East				
X Coordinate:	-121.26799				
Y Coordinate:	38.7083				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	548	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$54,800.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5652
Location:	Hanson Ave - South				
X Coordinate:	-121.26763				
Y Coordinate:	38.70982				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	217	Quantity:	LF	
Description:	No pedestrian route provided			
As Built Desc:	No sidewalk provided			
Solution:	Construct new firm and stable pedestrian route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$21,700.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5653
Location:	Hanson Ave - South				
X Coordinate:	-121.26714				
Y Coordinate:	38.70983				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB	
Description:	No barricade provided where sidewalk ends in hazardous location			
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk			
Solution:	Provide barricade with cane detectable warning at end of sidewalk			
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/1/2011	Report Date:	3/1/2011	Barrier #:	5654
Location:	Hanson Ave - South				
X Coordinate:	-121.26706				
Y Coordinate:	38.70982				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	107	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$13,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5655
Location:	Hanson Ave - North				
X Coordinate:	-121.26675				
Y Coordinate:	38.70992				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.6% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$12,500.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5656
Location:	Hanson Ave - North				
X Coordinate:	-121.26709				
Y Coordinate:	38.7099				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB
Description:	No barricade provided where sidewalk ends in hazardous location		
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk		
Solution:	Provide barricade with cane detectable warning at end of sidewalk		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5657
Location:	Hanson Ave - North				
X Coordinate:	-121.26713				
Y Coordinate:	38.7099				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	700	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$70,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5658
Location:	Wonder St - East				
X Coordinate:	-121.26942				
Y Coordinate:	38.70998				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1183	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$118,300.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5659
Location:	Madera Park Entrance - Corner B				
X Coordinate:	-121.26938				
Y Coordinate:	38.71335				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5660
Location:	Madera Park Entrance - Corner C				
X Coordinate:	-121.26939				
Y Coordinate:	38.71324				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH	
Description:	No truncated domes provided at transition into roadway			
As Built Desc:	No detectable warning provided			
Solution:	Provide compliant truncated domes			
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5661
Location:	Wonder St - East				
X Coordinate:	-121.26939				
Y Coordinate:	38.71335				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	580	Quantity:	LF	
Description:	No pedestrian route provided			
As Built Desc:	No sidewalk provided			
Solution:	Construct new firm and stable pedestrian route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$58,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5662
Location:	Wonder St - West				
X Coordinate:	-121.26942				
Y Coordinate:	38.71492				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	520	Quantity:	LF	
Description:	No pedestrian route provided			
As Built Desc:	No sidewalk provided			
Solution:	Construct new firm and stable pedestrian route			
Bar. Severity:	1 Necessary	Cost Estimate:	\$52,000.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5663
Location:	Wonder St and Stanford Ave - Corner A				
X Coordinate:	-121.26946				
Y Coordinate:	38.71348				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH	
Description:	No truncated domes provided at transition into roadway			
As Built Desc:	No detectable warning provided			
Solution:	Provide compliant truncated domes			
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:
Implementation Priority:	4	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	Two - way intersection corners A,D
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5664
Location:	Wonder St and Stanford Ave - Corner D				
X Coordinate:	-121.26954				
Y Coordinate:	38.71332				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes: Two - way intersection corners A,D

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5665
Location:	Stanford Ave - North				
X Coordinate:	-121.26958				
Y Coordinate:	38.71341				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	600	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$60,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5666
Location:	Stanford Ave - South				
X Coordinate:	-121.2716				
Y Coordinate:	38.71336				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	620	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$62,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5667
Location:	Wonder St - West				
X Coordinate:	-121.26947				
Y Coordinate:	38.71324				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1220	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$122,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5668

Location: Hanson Ave - North

X Coordinate: -121.26961

Y Coordinate: 38.70986

Barrier Area: Sidewalks

Barrier Type: No sidewalk

Code Ref: CBC 1127B.1 and ADA/ABA 206.2.1



As Built Meas: 600 Quantity: LF

Description: No pedestrian route provided

As Built Desc: No sidewalk provided

Solution: Construct new firm and stable pedestrian route

Bar. Severity: 1 Necessary Cost Estimate: \$60,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5669

Location: Hanson Ave - South

X Coordinate: -121.27161

Y Coordinate: 38.7098

Barrier Area: Sidewalks

Barrier Type: No sidewalk

Code Ref: CBC 1127B.1 and ADA/ABA 206.2.1



As Built Meas: 600 Quantity: LF

Description: No pedestrian route provided

As Built Desc: No sidewalk provided

Solution: Construct new firm and stable pedestrian route

Bar. Severity: 1 Necessary Cost Estimate: \$60,000.00 Status:

Implementation Priority: 4 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5670
Location:	Wonder St - West				
X Coordinate:	-121.26948				
Y Coordinate:	38.70971				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	750	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$75,000.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5671
Location:	Antelope Rd - North				
X Coordinate:	-121.26986				
Y Coordinate:	38.70776				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	207	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$25,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5672
Location:	Antelope Rd - North				
X Coordinate:	-121.27061				
Y Coordinate:	38.70777				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB		
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided				
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder				
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5673
Location:	Antelope Rd - North				
X Coordinate:	-121.27069				
Y Coordinate:	38.70777				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF		
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.7% cross slope				
Solution:	Provide min. 48" wide level walkway through driveway				
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,250.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5674
Location:	Antelope Rd - North				
X Coordinate:	-121.27085				
Y Coordinate:	38.70777				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	35	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5675
Location:	Antelope Rd - South				
X Coordinate:	-121.27132				
Y Coordinate:	38.70755				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.8% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5676
Location:	Antelope Rd - South				
X Coordinate:	-121.2711				
Y Coordinate:	38.70754				
Barrier Area:	Sidewalks				
Barrier Type:	Elbow in Sidewalk - Cross Slope (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	150	Quantity:	LF
Description:	Cross slope at elbow exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.5% cross slope		
Solution:	Demolish existing and construct new sidewalk without curb ramp		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$18,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5677
Location:	Antelope Rd - South				
X Coordinate:	-121.2706				
Y Coordinate:	38.70754				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	46	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.0% cross slope cracked concrete		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$5,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5678

Location: Antelope Rd - South

X Coordinate: -121.27041

Y Coordinate: 38.70752

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 113 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.5% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$14,125.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5679

Location: Antelope Rd - South

X Coordinate: -121.26985

Y Coordinate: 38.70755

Barrier Area: Curb Ramps

Barrier Type: No Curb Ramp - Depressed Existing Curb

Code Ref: CBC 1127B.5.1 and ADA/ABA 402.2



As Built Meas: 1 Quantity: EACH

Description: No compliant curb cut at corner (intersection)

As Built Desc: 8.6% running slope at depressed area

Solution: Demolish existing and construct curb cut

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes: Two -way intersection corners C,D

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5680
Location:	Antelope Rd - South				
X Coordinate:	-121.27007				
Y Coordinate:	38.70755				
Barrier Area:	Curb Ramps				
Barrier Type:	No Curb Ramp - Depressed Existing Curb				
Code Ref:	CBC 1127B.5.1 and ADA/ABA 402.2				



As Built Meas:	1	Quantity:	EACH
Description:	No compliant curb cut at corner (intersection)		
As Built Desc:	10.8% running slope at depressed area		
Solution:	Demolish existing and construct curb cut		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:	Two -way intersection corners C,D		

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5681
Location:	Antelope Rd - South				
X Coordinate:	-121.26983				
Y Coordinate:	38.70755				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	87	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$10,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5682
Location:	Antelope Rd - South				
X Coordinate:	-121.26937				
Y Coordinate:	38.70746				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.6% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5683
Location:	Antelope Rd - West				
X Coordinate:	-121.26905				
Y Coordinate:	38.70742				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	430	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$53,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5684
Location:	Antelope Rd - West				
X Coordinate:	-121.26805				
Y Coordinate:	38.70651				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF		
Description:	Driveway cross slope exceeds 2.0% (4.1% to 4.9%)				
As Built Desc:	4.0% cross slope				
Solution:	Provide min. 48" wide level walkway through driveway				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$5,000.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5685
Location:	Antelope Rd - West				
X Coordinate:	-121.26792				
Y Coordinate:	38.70631				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	100	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.2% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$12,500.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5686A
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26791				
Y Coordinate:	38.70591				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	385	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.5% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$48,125.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5686B
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26799				
Y Coordinate:	38.70587				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF		
Description:	Change in level greater than 1/2"				
As Built Desc:	1/2" lip in sidewalk surface				
Solution:	Grind or repair sidewalk to remove trip hazard				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5686C
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26803				
Y Coordinate:	38.70585				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	5	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5687
Location:	Old Auburn Rd - North				
X Coordinate:	-121.2691				
Y Coordinate:	38.70541				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	20	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	11.4% cross slope, 12.3% running slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5688
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26922				
Y Coordinate:	38.70532				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5689
Location:	Old Auburn Rd - North				
X Coordinate:	-121.26923				
Y Coordinate:	38.70529				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Cane Detectable Barricade				
Code Ref:	CBC 1133B.8.6 and MUTCD Section 6D.02				



As Built Meas:	8	Quantity:	LF
Description:	No cane detectable warning on existing barricade		
As Built Desc:	Existing barricade lacks warning for the visually impaired		
Solution:	Provide cane detectable warning on barricade (max. 6" above ground)		
Bar. Severity:	1 Necessary	Cost Estimate:	\$800.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5690
Location:	Old Auburn Rd - North				
X Coordinate:	-121.2704				
Y Coordinate:	38.70468				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	165	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.1% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$20,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5691
Location:	Old Auburn Rd - North				
X Coordinate:	-121.27086				
Y Coordinate:	38.70447				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5692
Location:	Old Auburn Rd - North				
X Coordinate:	-121.27086				
Y Coordinate:	38.7045				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB	
Description:	No barricade provided where sidewalk ends in hazardous location			
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk			
Solution:	Provide barricade with cane detectable warning at end of sidewalk			
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5693
Location:	Old Auburn Rd - North				
X Coordinate:	-121.27093				
Y Coordinate:	38.70449				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	55	Quantity:	LF	
Description:	Driveway cross slope exceeds 2.0% (2.1% to 3.0%)			
As Built Desc:	3.6% cross slope			
Solution:	Provide min. 48" wide level walkway through driveway			
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,875.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5694
Location:	Old Auburn Rd - North				
X Coordinate:	-121.27124				
Y Coordinate:	38.70429				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	48	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$6,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5695
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27165				
Y Coordinate:	38.70459				
Barrier Area:	Sidewalks				
Barrier Type:	Abrupt Change in Level - > 1/2"				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 303.3				



As Built Meas:	8	Quantity:	LF
Description:	Change in level greater than 1/2"		
As Built Desc:	1/2" lip in sidewalk surface		
Solution:	Grind or repair sidewalk to remove trip hazard		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5696
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.70468				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	38	Quantity:	LF		
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.0% cross slope				
Solution:	Provide min. 48" wide level walkway through driveway				
Bar. Severity:	4 Low Severity	Cost Estimate:	\$4,750.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5697
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27171				
Y Coordinate:	38.70481				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	5	Quantity:	LF		
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)				
As Built Desc:	24" clear width due to guide wire				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					
Notes:					

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5698
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2717				
Y Coordinate:	38.70495				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	40	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	3.7% cross slope cracked concrete		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	1 Necessary	Cost Estimate:	\$5,000.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5699
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2717				
Y Coordinate:	38.70509				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	73	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.4% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$9,125.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5700
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.70534				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	53	Quantity:	LF	
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)			
As Built Desc:	8.6% cross slope			
Solution:	Provide min. 48" wide level walkway through driveway			
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,625.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5701
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27166				
Y Coordinate:	38.70545				
Barrier Area:	Sidewalks				
Barrier Type:	Ped Route -12" Grooves Incorrect Application				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	JOB	
Description:	12" grooves required only at curb ramps identified within sidewalk			
As Built Desc:	12" grooves incorrectly provided where no curb ramp exists			
Solution:	No remediation recommended until new construction is performed in area			
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00	Status:
Implementation Priority:	1	Facility Function:		
Implementation Phase:		Implementation Date:		
Official Responsible:				

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5702
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27169				
Y Coordinate:	38.70561				
Barrier Area:	Sidewalks				
Barrier Type:	Ped Route -12" Grooves Incorrect Application				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	JOB
Description:	12" grooves required only at curb ramps identified within sidewalk		
As Built Desc:	12" grooves incorrectly provided where no curb ramp exists		
Solution:	No remediation recommended until new construction is performed in area		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5703
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2717				
Y Coordinate:	38.70566				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	54	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$6,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5704
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27165				
Y Coordinate:	38.70585				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	37	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	7.5% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$4,625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5705
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27166				
Y Coordinate:	38.70594				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	22	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$2,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5706

Location: Sunrise Blvd - East

X Coordinate: -121.27165

Y Coordinate: 38.70599

Barrier Area: Sidewalks

Barrier Type: Driveway - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 46 Quantity: LF

Description: Driveway cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 6.7% cross slope

Solution: Provide min. 48" wide level walkway through driveway

Bar. Severity: 4 Low Severity Cost Estimate: \$5,750.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/3/2011 Report Date: 3/3/2011 Barrier #: 5707

Location: Sunrise Blvd - East

X Coordinate: -121.27167

Y Coordinate: 38.70613

Barrier Area: Sidewalks

Barrier Type: Cross Slope - Existing (5.0% or more)

Code Ref: CBC 1133B.7.1.3 and ADA/ABA 403.3



As Built Meas: 66 Quantity: LF

Description: Cross slope exceeds 2.0% (5.0% or more)

As Built Desc: 5.6% cross slope

Solution: Demolish existing and construct new route

Bar. Severity: 1 Necessary Cost Estimate: \$8,250.00 Status:

Implementation Priority: 1 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5708
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.70657				
Barrier Area:	Sidewalks				
Barrier Type:	Surface Condition - Damaged				
Code Ref:	CBC 1133B.7.1 and ADA/ABA 302.1				



As Built Meas:	56	Quantity:	LF
Description:	Surface is not firm and stable (cracked, broken or loose soil, etc.)		
As Built Desc:	cracked concrete		
Solution:	Repair surface to make firm and stable		
Bar. Severity:	1 Necessary	Cost Estimate:	\$7,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5709
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27164				
Y Coordinate:	38.70661				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	190	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$23,750.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5710
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27161				
Y Coordinate:	38.70716				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - 12" Grooves Incorrect Application				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	JOB
Description:	12" grooves required only at curb ramps identified at transition into driveway		
As Built Desc:	12" grooves incorrectly provided where no curb ramp exists		
Solution:	No remediation recommended, until new construction is performed in area		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5711
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2716				
Y Coordinate:	38.70714				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Running Slope in New Construction				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	5	Quantity:	LF
Description:	Transition ramp into driveway not compliant (slope exceeds 8.3%)		
As Built Desc:	9.4% running slope		
Solution:	Demolish existing and construct new transition ramp		
Bar. Severity:	1 Necessary	Cost Estimate:	\$625.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5712
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27165				
Y Coordinate:	38.70736				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	60	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.8% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$7,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5713
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27161				
Y Coordinate:	38.70789				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	31	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.2% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$3,875.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5714B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2716				
Y Coordinate:	38.70796				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Depth				
Code Ref:	ADAAG 4.37.1 and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat depth not 20" - 24" deep		
As Built Desc:	12" bench seat depth		
Solution:	Provide min. 1 accessible bench at bench stop		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$775.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5714A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2716				
Y Coordinate:	38.70796				
Barrier Area:	Bus Stops and Shelters				
Barrier Type:	Bench Seat Height				
Code Ref:	ADAAG 4.37.3* and ADA/ABA 903.4				



As Built Meas:	1	Quantity:	EACH
Description:	Bench seat height not between 17" - 19"		
As Built Desc:	20" bench seat height		
Solution:	Provide new compliant bench or remount at compliant height where possible		
Bar. Severity:	3 Hindrance	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5715
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2716				
Y Coordinate:	38.70823				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	50	Quantity:	LF
Description:	Driveway cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.0% cross slope		
Solution:	Provide min. 48" wide level walkway through driveway		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$6,250.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5716
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27161				
Y Coordinate:	38.70839				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided		
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder		
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists		
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5717
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.70846				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	260	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.1% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$32,500.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5718
Location:	Sunrise Blvd and Hanson Ave - Corner B				
X Coordinate:	-121.27165				
Y Coordinate:	38.70985				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5719
Location:	Sunrise Blvd and Hanson Ave - Corner C				
X Coordinate:	-121.27165				
Y Coordinate:	38.70977				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH
Description:	No truncated domes provided at transition into roadway		
As Built Desc:	No detectable warning provided		
Solution:	Provide compliant truncated domes		
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5720
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27169				
Y Coordinate:	38.71004				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	211	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.7% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$26,375.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5721
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27168				
Y Coordinate:	38.71059				
Barrier Area:	Sidewalks				
Barrier Type:	Drop-off Along Ped Route (> 4")				
Code Ref:	CBC 1133B.8.1				



As Built Meas:	2240	Quantity:	LF
Description:	Drop of more than 4" along pedestrian route lacks warning curb		
As Built Desc:	24" drop off creates hazardous condition for the visually impaired		
Solution:	Provide curb projecting at least 6" above the walk or sidewalk surface to warn the blind of a potent		
Bar. Severity:	1 Necessary	Cost Estimate:	\$392,000.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5722
Location:	Sunrise Blvd - East				
X Coordinate:	-121.2717				
Y Coordinate:	38.71121				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (2.1% to 3.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	206	Quantity:	LF
Description:	Cross slope exceeds 2.0% (2.1% to 3.0%)		
As Built Desc:	2.8% cross slope		
Solution:	Low severity barrier - no remediation recommended		
Bar. Severity:	4 Low Severity	Cost Estimate:	\$0.00
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5723
Location:	Sunrise Blvd and Stanford Ave - Corner B				
X Coordinate:	-121.27164				
Y Coordinate:	38.7134				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/3/2011	Report Date:	3/3/2011	Barrier #:	5724
Location:	Sunrise Blvd and Stanford Ave - Corner C				
X Coordinate:	-121.27165				
Y Coordinate:	38.71334				
Barrier Area:	Blended Transitions				
Barrier Type:	Detectable Warnings - Truncated Domes				
Code Ref:	CBC 1127B.5.3				



As Built Meas:	1	Quantity:	EACH		
Description:	No truncated domes provided at transition into roadway				
As Built Desc:	No detectable warning provided				
Solution:	Provide compliant truncated domes				
Bar. Severity:	2 Recommended	Cost Estimate:	\$1,400.00	Status:	
Implementation Priority:	1	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	Two - way intersection corners B,C
--------	------------------------------------

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5725
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.71347				
Barrier Area:	Sidewalks				
Barrier Type:	Drop-off Along Ped Route (> 4")				
Code Ref:	CBC 1133B.8.1				



As Built Meas:	405	Quantity:	LF
Description:	Drop of more than 4" along pedestrian route lacks warning curb		
As Built Desc:	6" drop off creates hazardous condition for the visually impaired		
Solution:	Provide curb projecting at least 6" above the walk or sidewalk surface to warn the blind of a potent		
Bar. Severity:	1 Necessary	Cost Estimate:	\$70,875.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5726
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27136				
Y Coordinate:	38.7169				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	182	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	5.6% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,750.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5727
Location:	Twin Oaks Ave - South				
X Coordinate:	-121.27143				
Y Coordinate:	38.71845				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	2227	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$222,700.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5728
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26378				
Y Coordinate:	38.71879				
Barrier Area:	Sidewalks				
Barrier Type:	No sidewalk				
Code Ref:	CBC 1127B.1 and ADA/ABA 206.2.1				



As Built Meas:	1627	Quantity:	LF
Description:	No pedestrian route provided		
As Built Desc:	No sidewalk provided		
Solution:	Construct new firm and stable pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$162,700.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5729
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26885				
Y Coordinate:	38.71871				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - Transition to Shoulder				
Code Ref:	CBC 1121B.2 and ADA/ABA 206.2.1				



As Built Meas:	1	Quantity:	JOB		
Description:	Sidewalk ends and no ramp to pedestrian shoulder is provided				
As Built Desc:	No ramp to shoulder to enable pedestrian travel onto existing shoulder				
Solution:	Provide transition ramp to paved shoulder where no opposite sidewalk exists				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5730
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26878				
Y Coordinate:	38.71869				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB		
Description:	No barricade provided where sidewalk ends in hazardous location				
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk				
Solution:	Provide barricade with cane detectable warning at end of sidewalk				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5731A
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26946				
Y Coordinate:	38.71871				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	130	Quantity:	LF
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)		
As Built Desc:	3.3% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	3 Hinderance	Cost Estimate:	\$16,250.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5731B
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.26934				
Y Coordinate:	38.7187				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	28" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5732A
Location:	Twin Oaks Ave and Blossom Hill Ct - Corner A				
X Coordinate:	-121.27017				
Y Coordinate:	38.71872				
Barrier Area:	Curb Ramps				
Barrier Type:	12" Grooves - Existing (>5.0%)				
Code Ref:	CBC 1127B.5.6				



As Built Meas:	1	Quantity:	EACH		
Description:	12" grooves at top of curb ramp are not level (>5.0%)				
As Built Desc:	5.0% at 12" grooves				
Solution:	Demolish existing and construct new curb ramp				
Bar. Severity:	1 Necessary	Cost Estimate:	\$2,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B. Corner B compliant

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5732B
Location:	Twin Oaks Ave and Blossom Hill Ct - Corner A				
X Coordinate:	-121.27017				
Y Coordinate:	38.71872				
Barrier Area:	Curb Ramps				
Barrier Type:	Running Slope - Existing (9.5% or more)				
Code Ref:	CBC 1127B.5.3 and ADA/ABA 406.1				



As Built Meas:	1	Quantity:	EACH		
Description:	Ramp run cross slope exceeds 2.0% (9.5% or more)				
As Built Desc:	11.1% running slope				
Solution:	Demolish existing and construct new curb ramp				
Bar. Severity:	1 Necessary	Cost Estimate:	\$0.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes: Two - way intersection corners A,B. Corner B compliant

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5733
Location:	Blossom Hill Ct - East				
X Coordinate:	-121.26993				
Y Coordinate:	38.71886				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	315	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (5.0% or more)				
As Built Desc:	5.1% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	1 Necessary	Cost Estimate:	\$39,375.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5734
Location:	Blossom Hill Ct - East				
X Coordinate:	-121.26987				
Y Coordinate:	38.71963				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	85	Quantity:	LF		
Description:	Cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	3.7% cross slope				
Solution:	Demolish existing and construct new route				
Bar. Severity:	3 Hinderance	Cost Estimate:	\$10,625.00	Status:	
Implementation Priority:	4	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5735
Location:	Blossom Hill Ct - West				
X Coordinate:	-121.27026				
Y Coordinate:	38.71947				
Barrier Area:	Sidewalks				
Barrier Type:	Cross Slope - Existing (4.1% to 4.9%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	435	Quantity:	LF
Description:	Cross slope exceeds 2.0% (4.1% to 4.9%)		
As Built Desc:	4.7% cross slope		
Solution:	Demolish existing and construct new route		
Bar. Severity:	2 Recommended	Cost Estimate:	\$54,375.00
Implementation Priority:	4	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5736
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.27057				
Y Coordinate:	38.71868				
Barrier Area:	Sidewalks				
Barrier Type:	Clear Width - Existing ($\leq 31"$ or less)				
Code Ref:	CBC 1133B.7.1				



As Built Meas:	4	Quantity:	LF
Description:	Pedestrian route is not min. 48" wide ($\leq 31"$ or less)		
As Built Desc:	24" clear width due to pole		
Solution:	Demolish existing and construct new route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$500.00
Implementation Priority:	2	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			

Notes:	
--------	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5737
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.27076				
Y Coordinate:	38.71866				
Barrier Area:	Sidewalks				
Barrier Type:	Driveway - Existing (3.1% to 4.0%)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	116	Quantity:	LF		
Description:	Driveway cross slope exceeds 2.0% (3.1% to 4.0%)				
As Built Desc:	4.0% cross slope				
Solution:	Provide min. 48" wide level walkway through driveway				
Bar. Severity:	2 Recommended	Cost Estimate:	\$14,500.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5738
Location:	Twin Oaks Ave - North				
X Coordinate:	-121.27114				
Y Coordinate:	38.71874				
Barrier Area:	Sidewalks				
Barrier Type:	No Sidewalk - No Barricade				
Code Ref:	MUTCD Section 6D.01				



As Built Meas:	1	Quantity:	JOB		
Description:	No barricade provided where sidewalk ends in hazardous location				
As Built Desc:	No barricade or other warning provided for the visually impaired at end of sidewalk				
Solution:	Provide barricade with cane detectable warning at end of sidewalk				
Bar. Severity:	1 Necessary	Cost Estimate:	\$1,350.00	Status:	
Implementation Priority:	2	Facility Function:			
Implementation Phase:		Implementation Date:			
Official Responsible:					

Notes:					
--------	--	--	--	--	--

Field Date: 3/4/2011 Report Date: 3/4/2011 Barrier #: 5739

Location: Twin Oaks Ave - North

X Coordinate: -121.2712

Y Coordinate: 38.71865

Barrier Area: Sidewalks

Barrier Type: No Sidewalk - Transition to Shoulder

Code Ref: CBC 1121B.2 and ADA/ABA 206.2.1



As Built Meas: 1 Quantity: JOB

Description: Sidewalk ends and no ramp to pedestrian shoulder is provided

As Built Desc: No ramp to shoulder to enable pedestrian travel onto existing shoulder

Solution: Provide transition ramp to paved shoulder where no opposite sidewalk exists

Bar. Severity: 1 Necessary Cost Estimate: \$2,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date: 3/4/2011 Report Date: 3/4/2011 Barrier #: 5740

Location: Twin Oaks Ave - North

X Coordinate: -121.2716

Y Coordinate: 38.71868

Barrier Area: Sidewalks

Barrier Type: No sidewalk

Code Ref: CBC 1127B.1 and ADA/ABA 206.2.1



As Built Meas: 255 Quantity: LF

Description: No pedestrian route provided

As Built Desc: No sidewalk provided

Solution: Construct new firm and stable pedestrian route

Bar. Severity: 1 Necessary Cost Estimate: \$25,500.00 Status:

Implementation Priority: 2 Facility Function:

Implementation Phase: Implementation Date:

Official Responsible:

Notes:

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5741
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27161				
Y Coordinate:	38.719				
Barrier Area:	Sidewalks				
Barrier Type:	Drop-off Along Ped Route (> 4")				
Code Ref:	CBC 1133B.8.1				



As Built Meas:	129	Quantity:	LF
Description:	Drop of more than 4" along pedestrian route lacks warning curb		
As Built Desc:	8" drop off creates hazardous condition for the visually impaired		
Solution:	Provide curb projecting at least 6" above the walk or sidewalk surface to warn the blind of a potent		
Bar. Severity:	1 Necessary	Cost Estimate:	\$22,575.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5742A
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27167				
Y Coordinate:	38.71923				
Barrier Area:	Sidewalks				
Barrier Type:	Shoulder Cross Slope - Existing (5.0% or more)				
Code Ref:	CBC 1133B.7.1.3 and ADA/ABA 403.3				



As Built Meas:	650	Quantity:	LF
Description:	Cross slope exceeds 2.0% (5.0% or more)		
As Built Desc:	6.8% cross slope		
Solution:	Demolish existing and construct new pedestrian route		
Bar. Severity:	1 Necessary	Cost Estimate:	\$81,250.00
Status:			
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Field Date:	3/4/2011	Report Date:	3/4/2011	Barrier #:	5742B
Location:	Sunrise Blvd - East				
X Coordinate:	-121.27171				
Y Coordinate:	38.7195				
Barrier Area:	Sidewalks				
Barrier Type:	Drop-off Along Ped Route (> 4")				
Code Ref:	CBC 1133B.8.1				



As Built Meas:	36	Quantity:	LF
Description:	Drop of more than 4" along pedestrian route lacks warning curb		
As Built Desc:	8" drop off creates hazardous condition for the visually impaired		
Solution:	Provide curb projecting at least 6" above the walk or sidewalk surface to warn the blind of a potent		
Bar. Severity:	1 Necessary	Cost Estimate:	\$6,300.00
		Status:	
Implementation Priority:	1	Facility Function:	
Implementation Phase:		Implementation Date:	
Official Responsible:			
Notes:			

Cost Estimate Total Summary :	\$17,105,350.00
--------------------------------------	-----------------

Cost Estimate - Priority 1:	\$1,818,050.00
------------------------------------	----------------

Cost Estimate - Priority 2:	\$2,070,800.00
------------------------------------	----------------

Cost Estimate - Priority 3:	\$1,589,125.00
------------------------------------	----------------

Cost Estimate - Priority 4:	\$11,627,375.00
------------------------------------	-----------------
